


# LABORATORY ANALYSIS



11525 Rock Island Court, St. Louis, MO 63043  
Tel: 1-800-876-0008 info@englube.com

**NuVista Energy**  
10508 67 Ave, #201  
Grande Prairie, AB  
CA T8W 0K8  
Contact: Eldon Weaver  
eweaver@nvaenergy.com  
T:  
F:



Equipment No. **K602**  
System **Natural Gas Compression Engine**  
Oil Type **PETRO CANADA SENTRON LD 3000 (--- LTR)**

## DIAGNOSIS

The oil is near the end of its useful service life, recommend schedule an oil change. Resample at the next service interval to monitor. All component wear rates are normal. The water content is negligible. There is no indication of any contamination in the oil. Calcium ppm levels are abnormally high. The AN level is acceptable for this fluid.

## SAMPLE INFORMATION

Lab Number	New	<b>0261-03136</b>	9000-00647	9000-00644
Date of Sample	(Typical)	<b>17 Jan 2024</b>	25 Oct 2023	29 Sep 2023
Oil Added		<b>UNK</b>	UNK	UNK
Last Drain Date		--	--	--
Months on Sample		<b>0.0</b>	548.0	5477.0
Last Filter Service		--	--	--
Sample Point		---	---	---
Sample Status		<b>NORMAL</b>	NORMAL	NORMAL

## CONTAMINATION

Water	>0.1	<b>NEG</b>	NEG	NEG
-------	------	------------	-----	-----

**Customer Id:** NUVGRA  
**Sample No.:** PC0085494  
**Lab Number:** 02613136  
**Test Package:** PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Bill Quesnel CLS, OMA II, MLA-III, LLA-I +1  
(289)291-4641 x4641  
[Bill.Quesnel@wearcheck.com](mailto:Bill.Quesnel@wearcheck.com)

To change component or sample information:  
Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

# OIL ANALYSIS REPORT

