## LABORATORY ANALYSIS



11525 Rock Island Court, St. Louis, MO 63043 Tel: 1-800-876-0008 info@englube.com

**PLANET TOOL & ENGINEERING** 

315 COOL SPRINGS ROAD

O`FALLON, MO US 63366

Contact: Dave Diedrich ddiedrich@planet-tool.com

T: (636)379-9800

F:

Department CNC

Equipment No. O-12 5-AXIS Machine Center (X0029)

System Machining Fluid

Oil Type ENGINEERED LUBRICANTS ENCOOL SS-7478EP-AS (45 GAL)

## DIAGNOSIS

Add ENGINEERED LUBRICANTS ENCOOL SS-7478EP-AS concentrate until reaching a dilution of 15:1. The desired refractometer reading for this reservoir is 3.59. Resubmit sample for testing. Add ENCOOL BASE PH-1-2 to the reservoir in an area of high agitation. Circulate the reservoir for a minimum 15 minutes. Check pH for a minimum reading of 8.9. If the reading has not stabilized at or above an 8.9, repeat the same addition and circulation process until a pH minimum of 8.9 has been achieved. Inspect the reservoir for settled chips/fines, tramp oils, physical growth and remove them before there is an accumulation. Add a "severe" dose of BioTech 084, to the tank side reservoir in an area of high agitation. Follow up three days later with a "maintenance" dose to stabilize the microbial additive package. Circulate the coolant daily for proper aeration. (not applicable) Excessively high bacteria counts. Elevated yeast counts. Ratio is too lean. Maintaining the desired ratio is the top priority for optimum coolant performance and longevity. The pH is marginally low. PH is a metric for overall coolant health and stability. Maintaining the desired pH assists with corrosion protection and is a microorganism deterrent.

SAMPLE INFORMATION					
Lab Number		New	2307-00266	2305-00432	2303-00068
Date of Sample		(Typical)	07 Jul 2023	08 May 2023	06 Mar 2023
Oil Added			UNK	UNK	UNK
Last Drain Date					
Last Filter Service					
Sample Point					
Sample Status			SEVERE	ABNORMAL	ABNORMAL
RATIO PER REFRACTOMETER					
Refract. Reading			1.2	3.2	3.0
Refract. Model			DIGITAL	DIGITAL	DIGITAL
Refract. Ratio	oil:water		<b>47:1</b>	<b>17:1</b>	■18:1
PH (ASTM E-70)					
рН	Scale 0-14		<b>▲</b> 8.3	<b>■</b> 9.1	■8.9
Ratio Rec`d	oil:water		AS REC'D	AS REC'D	AS REC'D
BACTERIA COU	NT (CL	ASS RANGE	E 0 TO 6)		
Bacteria Class	Scale 0-6		• 6	<b>▲</b> 3	<b>□</b> 0
FUNGUS COUNT (CLASS RANGES: YEAST 0 TO 4/MOLD 0 TO 3)					
Yeast Class	Scale 0-4		<b>3</b>	<b>□</b> 0	<u>^</u> 2
Mold Class	Scale 0-3		<b>□</b> 0	0	0

Customer Id: ENC0303701 Sample No.: EN23070266 Lab Number: 23070266 Test Package: TEST



To manage this report scan the QR code

To discuss the diagnosis or test data: Brad Fritz +1 (314)872-9540 bfritz@englube.com

To change component or sample information: Tracy Weaks +1 (314)872-9540 tweaks@englube.com

## **FUEL REPORT**

