

LABORATORY ANALYSIS



11525 Rock Island Court, St. Louis, MO 63043
Tel: 1-800-876-0008 info@englube.com

ASHLEY ENERGY LLC
ONE ASHLEY ST.
ST LOUIS, MO
United States 63102
Contact: Service Manager

Equipment No. **#2 GAS TURBINE (00001)**
System **Unknown Component**
Oil Type **SHELL TURBO T ISO 32 (--- GAL)**

T:
F:

DIAGNOSIS

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. There is a trace of moisture present in the sample. The condition of the sample is acceptable for the time in service.

SAMPLE INFORMATION

Lab Number	New	2309-00069	2308-01620	---
Date of Sample	(Typical)	05 Sep 2023	30 Aug 2023	---
Oil Added		UNK	UNK	---
Last Drain Date		--	--	---
Last Filter Service		--	--	---
Sample Point		---	---	---
Sample Status		MARGINAL	ATTENTION	---

% WATER - KARL FISCHER (ASTM E203)

% Water (KF)	%	▲ 0.118	▲ 0.139	---
ppm Water (KF)	ppm	▲ 1,180	▲ 1,390	---

Customer Id: ENC0133F01
Sample No.: EN23090069
Lab Number: 23090069
Test Package: TEST



To manage this report scan the QR code

To discuss the diagnosis or test data:

Tracy Weaks +1 (314)872-9540
tweaks@englube.com

To change component or sample information:

Tracy Weaks +1 (314)872-9540
tweaks@englube.com

OIL ANALYSIS REPORT

