LABORATORY ANALYSIS



11525 Rock Island Court, St. Louis, MO 63043 Tel: 1-800-876-0008 info@englube.com

SPIRE

14905 SINKS RD. FLORRISANT, MO United States 63034 Contact: Service Manager

T:

F:

COMPRESSOR #2 OIL (00017) Equipment No.

SAMPLE INFORMATION

System **Unknown Component**

Oil Type CITGO PACEMAKER 1240 (--- GAL)

DIAGNOSIS

We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.Copper (Cu) ppm levels are marginal. All other component wear rates are normal. There is no indication of any contamination in the sample. The condition of the sample is acceptable for the time in service.

Lab Number		New	2311-00103		
Date of Sample		(Typical)	03 Nov 2023		
Oil Added			UNK		
Last Drain Date					
Last Filter Service					
Sample Point					
Sample Status			MARGINAL		
VISCOSITY @ 100F OR 40C (ASTM D-445)					
-		1100 (710111	•		
SSU Vis. @ 100F	SSU		709.7		
% WATER - KARL FISCHER (ASTM E203)					
% Water (KF)	%		0.067		
ppm Water (KF)	ppm		670		
ICP - OILS (REPORTED IN PARTS PER MILLION)					
,		DINT AITIOI	· ·		
Aluminum (Al)	ppm		<5		
Antimony (Sb)	ppm		<5		
Cadmium (Cd)	ppm		<5		
Chromium (Cr)	ppm		<5		
Cobalt (Co)	ppm		<5		
Copper (Cu)	ppm		<u>12</u>		
Iron (Fe)	ppm		25		
Lead (Pb)	ppm		12		
Manganese (Mn)	ppm		<5		
Molybdenum(Mo)	ppm		<5		
Nickel (Ni)	ppm		<5		
Silver (Ag)	ppm		<5		
Tin (Sn)	ppm		6		
Titanium (Ti)	ppm		<5		
Vanadium (V)	ppm		<5		
Barium (Ba)	ppm		<5		
Boron (B)	ppm		<5		
Calcium (Ca)	ppm		1,320		
Magnesium (Mg)	ppm		26		
Phosphorus(P)	ppm	500	■329		
Silicon (Si)	ppm		<5		
Zinc (Zn)	ppm		404		
Sulfur (S)	ppm		1,840		
(-)	1-1		.,		

Customer Id: ENC0134J01 **Sample No.:** EN23110103 Lab Number: 23110103 Test Package: TEST



To manage this report scan the QR code

To discuss the diagnosis or test data: Tracy Weaks +1 (314)872-9540 tweaks@englube.com

To change component or sample information: Tracy Weaks +1 (314)872-9540 tweaks@englube.com



OIL ANALYSIS REPORT

