# LABORATORY ANALYSIS



SPIRE

T: F:

14905 SINKS RD. FLORRISANT, MO United States 63034 Contact: Service Manager

Equipment No.

## COMPRESSOR #3 OIL (00018)

**Unknown Component** 

System Oil Type

### CITGO PACEMAKER 1240 (--- GAL)

#### DIAGNOSIS

We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.Copper (Cu) ppm levels are marginal. All other component wear rates are normal. There is no indication of any contamination in the sample. The condition of the sample is acceptable for the time in service.

Customer Id: ENC0134J01 Sample No.: EN23110104 Lab Number: 23110104 Test Package: TEST



To discuss the diagnosis or test data: Tracy Weaks +1 (314)872-9540 tweaks@englube.com

To change component or sample information: Tracy Weaks +1 (314)872-9540 tweaks@englube.com

SAMPLE INFORMATION					
Lab Number		New	2311-00104		
Date of Sample		(Typical)	03 Nov 2023		
Oil Added		,	UNK		
Last Drain Date					
Last Filter Service					
Sample Point					
Sample Status			MARGINAL		
VISCOSITY @ 1	00F OF	R 40C (ASTN	/I D-445)		
SSU Vis. @ 100F	SSU		692.2		
% WATER - KAP	RL FISC	CHER (ASTM	E203)		
% Water (KF)	%		0.046		
ppm Water (KF)	ppm		<b>460</b>		
ICP - OILS (REPORTED IN PARTS PER MILLION)					
Aluminum (Al)	ppm		<5		
Antimony (Sb)	ppm		<5		
Cadmium (Cd)	ppm		<5		
Chromium (Cr)	ppm		<5		
Cobalt (Co)	ppm		<5		
Copper (Cu)	ppm		<u> </u>		
Iron (Fe)	ppm		15		
Lead (Pb)	ppm		9		
Manganese (Mn)	ppm		<5		
Molybdenum(Mo)	ppm		<5		
Nickel (Ni)	ppm		<5		
Silver (Ag)	ppm		<5		
Tin (Sn)	ppm		7		
Titanium (Ti)	ppm		<5		
Vanadium (V)	ppm		<5		
Barium (Ba)	ppm		<5		
Boron (B)	ppm		<5		
Calcium (Ca)	ppm		1,240		
Magnesium (Mg)	ppm		12		
Phosphorus(P)	ppm	500	<b>305</b>		
Silicon (Si)	ppm		<5		
Zinc (Zn)	ppm		381		
Sulfur (S)	ppm		1,790		



# **OIL ANALYSIS REPORT**

