

LABORATORY ANALYSIS



11525 Rock Island Court, St. Louis, MO 63043
Tel: 1-800-876-0008 info@englube.com

Department **REYLAM - DIECAST**
 Equipment No. **THT05 DIECASTER UNIT #5 (00016)**
 System **Water**
 Oil Type **ENGINEERED LUBRICANTS ENLUBE 205-FR (150 GAL)**

COPELAND (MHDS)
 6001 S. 35TH STREET, SUITE D"
 REYNOSA, ZZ
 US
 Contact: GERARDO GUERRERO
 francisco.castillo@Copeland.com
 T:
 F:

Diagnosis

Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. There is no indication of any contamination in the oil. The system and fluid cleanliness is acceptable. The condition of the oil is acceptable for the time in service.

Sample Information

Lab Number	New	2401-00414	2311-00183	2309-00510
Date of Sample	(Typical)	10 Jan 2024	06 Nov 2023	11 Sep 2023
Oil Added		UNK	UNK	UNK
Last Drain Date		--	--	--
Months on Sample		220.8	218.7	216.9
Last Filter Service		--	--	--
Sample Point		---	---	---
Sample Status		NORMAL	ABNORMAL	NORMAL

VISCOSITY @ 100F or 40C (ASTM D-445)

SSU Vis. @ 100F	SSU	213.0	247.4	228.4	233.0
cSt Vis. @ 40C	cSt	46.0	49.25	45.44	46.36

ALKALINE RESERVE (ADDITION OF DEIONIZED WATER IS PREFERRED)

Alkaline Reserve		178	178	177
------------------	--	------------	-----	-----

Hiac Particle Count/ISO 4406

4 Micron & Larger	particles/ml	>40000	2,579	23,839	3,419
6 Micron & Larger	particles/ml	>5000	1,034	7,163	1,081
14 Micron & Larger	particles/ml	>320	182	300	133
ISO Code	ISO 4406(c)	>22/19/15	19/17/15	22/20/15	19/17/14

Contamination

Water		>55	NEG	NEG	NEG
-------	--	-----	------------	-----	-----

Customer Id: MOTMCA
 Sample No.: EN24010414
 Lab Number: 24010414
 Test Package: TEST



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Brian Klutenkamper +1 (314)872-9540
bklutenkamper@englube.com

To change component or sample information:
 Tracy Weaks +1 (314)872-9540
tweaks@englube.com

OIL ANALYSIS REPORT

