LABORATORY ANALYSIS



1525 Rock Island Court, St. Louis, MO 63043 Tel: 1-800-876-0008 info@englube.com

COPELAND (MHDS)

6001 S. 35TH STREET, SUITE D"" REYNOSA, ZZ

US

Contact: GERARDO GUERRERO francisco.castillo@Copeland.com

T: F:

Department REYLAM - DIECAST

Equipment No. IHS05 INDUCTION FURNACE(DIECAST 5) (X0062)

System Unknown Component

Oil Type ENGINEERED LUBRICANTS EL-IHS-DISTILLED WATER (--- GAL)

SAMPLE INFORMATION

DIAGNOSIS

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. There is no indication of any contamination in the sample. The condition of the sample is acceptable for the time in service.

Late Missaels as	Mann	0404 00400	0040 00544	0000 00004
Lab Number	New	2401-00423	2310-00511	2008-00694
Date of Sample	(Турі	,	27 Sep 2023	11 Aug 2020
Oil Added		UNK	UNK	UNK
Last Drain Date				
Last Filter Service				
Sample Point				
Sample Status		NORMAL	NORMAL	NORMAL
PH (ASTM E-70)			
pН	Scale 0-14	■ 9.7	6.6	6.9
Ratio Rec'd	oil:water	AS REC'D	AS REC'D	AS REC'D
HARDNESS (MO	G/L CACO3)			
Hardness (CaCO3)	mg/L	<6.6	<6.6	<6.6
Grains		<1.0	<1.0	<1.0
BACTERIA COL	JNT (CLASS	RANGE 0 TO 6)		
Bacteria Class	Scale 0-6	1	0	0
FUNGUS COUN	IT (CLASS R	ANGES: YEAST 0 T	O 4/MOLD 0 TO 3)	
Yeast Class	Scale 0-4	1	0	0
Mold Class	Scale 0-3	■ 0	0	0
CONDUCTIVITY	OF WATER			
Conductivity	Micromhos	218.0	29.3	27.9
CONTAMINATIO	N			
Water		NEG	NEG	NEG

Customer Id: MOTMCA Sample No.: EN24010423 Lab Number: 24010423 Test Package: TEST



To manage this report scan the QR code

To discuss the diagnosis or test data: Brian Klutenkamper +1 (314)872-9540 bklutenkamper@englube.com

To change component or sample information: Tracy Weaks +1 (314)872-9540 tweaks@englube.com



FUEL REPORT