


CALDERA #1


Customer: PTRHTF60001	System Information	Sample Information
LUBRIIMPORT S.A.	System Volume: 1230 ltr	Lab No: 01842982
5 AVENIDA 5-08 ZONA 9	Bulk Operating Temp: 500F / 260C	Analyst: Michael Kaufman
GUATEMALA CITY, GUATEMALA	Heating Source:	Sample Date: 06/05/13
Attn: RAUL DE LEON	Blanket:	Received Date: 06/10/13
Tel: 5(022)383-7777	Fluid: PETRO CANADA CALFLO AF	Completed: 07/19/13
E-Mail: rdeleon@lubriimport.com.gt	Make:	Michael Kaufman
		mkaufman@suncor.com

Recommendation: The oil is still very viscous as it appears to be about 3x the viscosity of Calflo AF (32 cSt). A high fluid viscosity will result in decreased thermal properties. Insoluble solids have improved slighly since the last report. Overall if this sample is a truly representative of the oil in the system, the fluid should be replaced soon.

Comments: Pentane Insolubles levels are severely high. Visc @ 40°C is severely high. (GCD) 90% Distillation Point is marginally high.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
06/05/13	06/10/13	0.0h	TANK DRAIN PIPE	417 / 214	47.0	98.6	0.21	3.22	697 / 370	799 / 426	907 / 486	1.37
02/12/13	02/19/13	12.0h	TUBERIA DEL TANQUE	439 / 226	313.9	102	0.19	5.19	700 / 371	802 / 428	913 / 489	1.69
02/01/13	02/04/13	2.0h	TUBERIA DEL TANQUE	437 / 225	30.8	1020	0.43	6.61	710 / 377	820 / 438	973 / 523	2.30





Historical Comments

02/12/13	The oil is still very viscous, as the viscosity is 100 cSt@40C, about 3x heavier than Calflo AF. Although this is much better than the 1000 cSt form the last sample. Oxidation (Acid Number) is lower too. Insoliuble Solids remain very high. Overall if this sample is a true representation of what circulates in the system this oil will need to be replaced in the near future. Remember that before collecting a sample, it is always recommended to flush the sampling piev/alve with 4 to 5 times the amount of oil that the piping holds and letting it drain in a metal bucket for disposal. This ensures we have a representative sample of what is circulating inside the system. Pentane Insolubles levels are severely high. (GCD) 90% Distillation Point is severely low. Visc @ 40°C is severely high. (GCD) % < 335°C is abnormally high. (GCD) 10% Distillation Point is marginally low.
02/01/13	The sample has a very high amount of solids. The viscosity is also extreme at 1000 cSt at 40C, about 33 times higher than fresh Calflo AF. To thicken the oil this much in only 2 months some type of contaminant must have entered the oil system. The oxidation level (TAN) is rising but is considered moderate at this point. If this sample is a true representation of the entire 1230L of fluid in this system this is a troubling situation that must be investiogated and fixed. Pentane Insolubles levels are severely high. (GCD) 90% Distillation Point is marginally high. Acid Number (AN) is abnormally high. (GCD) 50% Distillation Point is marginally high.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.