




HEAT TRANSFER SYSTEM



Customer: PTRHTF10025	System Information	Sample Information
LAKESIDE INDUSTRIES 8705 N.E. 117TH AVENUE VANCOUVER, WA 98662 US Attn: Chris Merringer Tel: (360)903-3695 E-Mail: chris.merringer@lakesideindustries.com	System Volume: 600 gal Bulk Operating Temp: 325F / 163C Heating Source: Blanket: Fluid: PETRO CANADA PETRO-THERM Make: HEATEC	Lab No: 01849092 Analyst: Michael Kaufman Sample Date: 06/13/13 Received Date: 07/08/13 Completed: 07/12/13 Michael Kaufman mkaufman@suncor.com

Recommendation: The oil is showing signs of improvement, probably due to a fluid top-up. The Acid number has decreased from 1.94 in Nov 2012 to 0.76, but we would still consider it high. High acid problems appear to date back to 2007. Acids form as a result of oxidation and their presence can be corrosive to the system over time. If this sample is representative of what is in the system, we recommend a partial fluid change-out help bring that acid number down.

Comments: Pentane Insolubles levels are severely high. Acid Number (AN) is severely high. (GCD) 90% Distillation Point is marginally high.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
06/13/13	07/08/13	6.0y	RETURN LINE B4 FLTR	448 / 231	47.4	38.4	0.760	1.60	715 / 380	810 / 432	911 / 489	0.94
11/10/12	11/13/12			437 / 225	93	43.1	1.94	1.833	705 / 374	804 / 429	903 / 484	2.852
02/08/12	02/16/12	4.0y	NA	408 / 209	106	41.7	1.51	1.015	705 / 374	803 / 429	898 / 481	3.002
06/21/11	06/30/11		BEFORE FILTER	401 / 205	64	41.3	1.07	0.889	710 / 376	807 / 430	901 / 483	2.54
06/23/10	07/06/10	3.0y	HEATECK	433 / 223	87	42.1	2.03	1.240	700 / 371	799 / 426	890 / 477	3.451
Baseline Data				433 / 223		34.2	0.03		707 / 375	799 / 426	887 / 475	2.6







Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
06/13/13	41	0	0	0	0	0	1	0	0	0	3	0	0	0	0	0	0	0	0	0	0	0	0	0
11/10/12	32	0	0	0	0	0	0	0	0	0	3	0	0	0	0	0	0	0	0	0	0	0	3	0
02/08/12	2	0	0	0	0	0	0	0	0	0	2	0	0	0	0	0	0	0	0	0	0	0	0	0
06/21/11	3	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	2	0	1	3	0
06/23/10	3	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	2	0
Baseline Data			0	0						0			0	0					0				0	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]


GCD Spectrum



Gas Chromatography Distillation



% Boiling < 335°C



Historical Comments

11/10/12	The rating system is inadequate and therefore falsely ranked this sample as "normal" when in fact this oil is in the "severe" category. The oxidation level, measured via the TAN analysis, shows the oil is oxidized way beyond what is tolerable. Oxidation
02/08/12	The overall oil condition worsened since the last sample from 7 months ago as the Total Acid Number increased from the already high 1.0 to 1.5 today. High TAN is normally associated with oxidation, a form of oil degradation. The high TAN problem dates back as far back as 2007. If this sample is truly representative of what is circulating in the system an oil replacement should be considered at some point. High TAN oil is more corrosive and will attack the piping and over time. We would rate the sample condition as more critical than the "green" rating it has now.
06/21/11	
06/23/10	

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.