[ATHABASCA OIL CORP / 08-28-078-10W4M] L4 (PAD D) LIESMER

Customer: PTRHTF20133

ATHABASCA OIL CORP.

LEISMER DEMONSTRATION PLANT

LSD2-79-10-W4M

NEAR CONKLIN, AB Canada

Attn: George Ball Tel: (587)233-1312 E-Mail: gball@atha.com

System Information

10.0

System Volume: 8000 ltr

Bulk Operating Temp: 212F / 100C

Heating Source:

Blanket:

Fluid: PETRO CANADA CALFLO LT Make: TORNADO TECHNOLOGIES


Sample Information


Lab No: 01889720 Analyst: Peter Harteveld Sample Date: 12/11/13 Received Date: 01/15/14 Completed: 01/22/14 Peter Harteveld

peter.harteveld@HFSinclair.com

Recommendation: TAN is high. This is most likely the result of oxidation taking place in the expansion tank of the system. The reported fluid temperature in the expansion tank is 120 degrees C. Sweetening of the fill is recommended. When loss of efficiency is suspected an inspection of system internals is recommended. For now it is recommended to lower the fluid temperature in the expansion tank and provide a N2 blanket to prevent contact with air (oxygen)

Comments: Acid Number (AN) is abnormally high.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.