



Recommendation: The oil viscosity has dropped significantly (35%) on this last sample. The drop of flash point to ~200F (from ~400F) and steep increase in low boilers could be 2 things. The oil was contaminated with a lighter material or it was thermally degraded. The rapid degradation due to the fire may cause such a rapid degradation of the fluid. If the entire charge of the system fluid looks like this sample it brings the difficult decision that the fluid should probably be replaced or do a significant sweetening to restore the flash point and other properties.

LeBlanc at (541)967-6499

Comments: (GCD) 90% Distillation Point is severely high. COC Flash Point is severely low. Visc @ 40°C is severely low. (GCD) % < 335°C is marginally high.

| Sample Date | Received Date | Fluid Age | Sample Location | Flash Point (COC) | Water (KF) | Viscosity (40°C) | Acid Number | Solids | GCD 10% | GCD 50% | GCD 90% | GCD % < 335°C |
|---------------|---------------|-----------|----------------------|------------------------|------------|------------------|--------------|--------|-----------|-----------|-----------|---------------|
| | mm/dd/yy | | | °F/°C | ppm | cSt | mg/KOH/ g | %wt | °F/°C | °F/°C | °F/°C | % |
| 07/07/16 | 07/12/16 | 49m | OIL LOOP DCS REBOILR | 198 / 92 | 96.4 | 18.0 | 0.05 | 0.066 | 640 / 338 | 793 / 423 | 936 / 502 | 9.21 |
| 01/18/16 | 01/25/16 | 49m | PRV VENT NEAR TCS VP | 392 / 200 | 30.2 | 28.0 | 0.16 | 0.136 | 684 / 362 | 796 / 425 | 898 / 481 | 4.13 |
| 11/21/15 | 11/27/15 | 0m | | 408 / 209 | 195.8 | 21.5 | 0.10 | 0.097 | 671 / 355 | 789 / 420 | 891 / 477 | 5.41 |
| 07/22/15 | 07/29/15 | 41m | PRV VENT NEAR TCS VP | 367 / 186 | 0.00 | 28.9 | 0.041 | 0.101 | 682 / 361 | 798 / 426 | 895 / 479 | 4.55 |
| 04/13/15 | 04/21/15 | 41m | PRV VENT NEAR TCS VP | <mark>378 / 192</mark> | 14.0 | 28.2 | 0.04 | 0.055 | 672 / 356 | 783 / 417 | 869 / 465 | 4.95 |
| 01/20/15 | 01/26/15 | 37m | PRVVENT NEAR TCSVAP | <mark>363 / 184</mark> | 11.4 | 28.2 | 0.029 | 0.042 | 687 / 364 | 775 / 413 | 868 / 465 | 0.52 |
| Baseline Data | | | | 435 / 224 | | 32.7 | 0.03 | | 693 / 367 | 790 / 421 | 887 / 475 | 2.5 |





Sample appears normal. Sample again in 3 months. COC Flash Point is marginally low.

04/13/15

The overall condition of the oil has improved since the previous sample. The flash point has dropped slightly and is marginally low. The (GCD) 90% distillation point has improved slightly. The Si has decreased significantly. Sample in 1 month suggested. COC Flash Point is marginally low. (GCD) 90% Distillation Point is marginally low.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.