


ATLANTIC STATES


Customer: PTRHTF10041	System Information	Sample Information			
KUTTNER LLC.	System Volume: 7000 gal	Lab No: 02098246			
211 N FRANKLIN ST	Bulk Operating Temp: 540F / 282C	Analyst: Neil Buchanan			
PORT WASHINGTON, WI 53074 USA	Heating Source:	Sample Date: 08/21/16			
Attn: DAVID ZINKY	Blanket:	Received Date: 09/19/16			
Tel: (262)284-4483	Fluid: N/A	Completed: 09/26/16			
E-Mail: d.zinky@kuttnerna.com	Make: WUERZ	Neil Buchanan			
		neil.buchanan@HFSinclair.com			

Recommendation: No reference fluid available. Viscosity at 40C appears low compared to previous samples. High Sodium and calcium contamination. TAN is acceptable.

Comments: COC Flash Point is severely high. Calcium ppm levels are severely high. Visc @ 40°C is severely low. Sodium ppm levels are abnormally high.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
08/21/16	09/19/16	18.0m	PUMP INLET	417 / 214	130.5	19.7	0.11	0.092	710 / 376	791 / 421	877 / 469	0.37
04/14/15	06/05/15	2.0m	PUMP INLET	428 / 220	199.7	28.1	0.15	0.061	709 / 376	791 / 422	870 / 465	0.45
12/22/10	01/10/11		PUMP INLET	405 / 207	430	24.4	0.27	0.070	704 / 374	774 / 412	847 / 453	0.301





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.