




## [HOT OIL SAMPLE STATION] SILANE 4.0 DISTILLATION



Customer: PTRHTF10093	System Information	Sample Information
REC GROUP 3322 ROAD N N.E. MOSES LAKE, WA 98837 USA Attn: Loren Poulson Tel: E-Mail: loren.poulson@recsilicon.com	System Volume: 50000 gal Bulk Operating Temp: 420F / 216C Heating Source: Blanket: Fluid: PETRO CANADA CALFLO AF Make: COEN	Lab No: 02149796 Analyst: Ron LeBlanc Sample Date: 05/31/17 Received Date: 06/05/17 Completed: 06/07/17 To discuss this report contact Ron LeBlanc at (541)678-7044

Recommendation: Sample appears normal. Resample in 3 months.

Comments:



Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
05/31/17	06/05/17	8m	DISTO HOT OIL	406 / 208	17.0	30.9	0.060	0.052	692 / 367	797 / 425	897 / 481	1.60
09/14/16	09/19/16	58m	HOT OIL SMPL STATION	424 / 218	184.2	31.4	0.12	0.713	694 / 368	795 / 424	898 / 481	1.30
07/28/16	08/02/16	58m	PRV VENT NR TCS VAP	288 / 142	11.3	19.3	0.05	0.051	609 / 321	788 / 420	893 / 479	10.84
07/22/16	07/26/16	58m	H/O DCS REBOILER S	288 / 142	5.8	20.1	0.08	0.068	646 / 341	786 / 419	891 / 477	8.75
07/19/16	07/21/16	58m	PRV VENT NEAR TCS	237 / 114	43.3	19.8	0.13	0.508	552 / 289	777 / 414	878 / 470	13.13
07/15/16	07/21/16	58m	DISTO HOT OIL RESULT	252 / 122	25.4	17.6	0.09	0.190	548 / 287	790 / 421	901 / 483	13.01
Baseline Data				435 / 224		32.7	0.03		693 / 367	790 / 421	887 / 475	2.5





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
05/31/17	36	0	0	0	0	0	0	0	0	0	4	0	0	0	0	0	0	0	0	0	0	0	231	0
09/14/16	21	0	0	0	0	0	0	0	0	0	5	1	0	0	0	0	0	0	0	0	0	0	260	1
07/28/16	25	0	0	0	0	0	0	0	0	0	4	0	0	0	0	0	0	0	0	0	0	0	42	0
07/22/16	50	0	0	0	0	0	0	0	0	0	6	1	0	0	0	0	0	0	0	0	0	0	62	0
07/19/16	79	0	0	0	0	0	0	0	0	0	9	1	0	0	0	1	0	0	0	0	0	0	49	0
07/15/16	55	0	0	0	0	0	0	0	0	0	7	1	0	0	0	0	0	0	0	0	0	0	29	0
<b>Baseline Data</b>			0	0						0		0	0						0				270	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



**Historical Comments**

09/14/16	Pentane is elevated indicating sediment. Filter cart should be run on oil to clean it up. Pentane Insolubles levels are severely high.
07/28/16	COC Flash Point is severely low. Visc @ 40°C is severely low. (GCD) 10% Distillation Point is abnormally low. (GCD) % < 335°C is marginally high. COC Flash Point is severely low. Visc @ 40°C is severely low. (GCD) 10% Distillation Point is abnormally low. (GCD) % < 335°C is marginally high.
07/22/16	COC Flash Point is severely low. Visc @ 40°C is abnormally low. (GCD) % < 335°C is marginally high. COC Flash Point is severely low. Visc @ 40°C is abnormally low. (GCD) % < 335°C is marginally high.
07/19/16	(GCD) 10% Distillation Point is severely low. COC Flash Point is severely low. (GCD) % < 335°C is abnormally high. Visc @ 40°C is abnormally low. Compared to the previous sample the viscosity improved slightly, the COC flash point lowered slightly, the (GCD) 10% is approximately 55C lower than normal. Pentane appears to be increasing significantly over the last 4 samples. Decision needs to be made if the fluid can continue to be run with the low viscosity and low COC flash point. Pentane Insolubles levels are abnormally high. (GCD) 10% Distillation Point is severely low. COC Flash Point is severely low. (GCD) % < 335°C is abnormally high. Visc @ 40°C is abnormally low.
07/15/16	(GCD) 10% Distillation Point is severely low. COC Flash Point is severely low. Visc @ 40°C is severely low. (GCD) % < 335°C is abnormally high. Pentane appears to be increasing significantly over the last 3 samples. Decision needs to be made if the fluid can continue to be run with the low viscosity and low COC flash point. (GCD) 10% Distillation Point is severely low. COC Flash Point is severely low. Visc @ 40°C is severely low. (GCD) % < 335°C is abnormally high.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.