

## [ATHABASCA OIL CORP / 05-27-078-10W4M] L3 (PAD C) LIESMER

## Customer: PTRHTF20133

ATHABASCA OIL CORP.

LEISMER DEMONSTRATION PLANT

LSD2-79-10-W4M

0.20

0.10

0.00

Dec11/13

Jul19/15

Jan 17/15

Jun19/16

Mar20/1

NEAR CONKLIN, AB Canada

Attn: George Ball Tel: (587)233-1312 E-Mail: gball@atha.com

## System Information

System Volume: 8000 ltr

Bulk Operating Temp: 212F / 100C

Heating Source:

Blanket:

Fluid: PETRO CANADA CALFLO LT Make: TORNADO TECHNOLOGIES

## Sample Information

Lab No: 02162066 Analyst: Peter Harteveld Sample Date: 07/22/17 Received Date: 08/08/17 Completed: 08/16/17 Peter Harteveld

160

155

150

Mar20/1


Jul22/17

Mar20/1

peter.harteveld@HFSinclair.com

Recommendation: The fluid is in a good condition and suitable for further use. It does show some degradation indicated by a higher percentage of boil-off <335C and an elevated 90% GCD temperature. It is recommended to vent-off low boiler vapors to atmosphere at a regular interval. (suggestion is once a month) Please re-sample in 12 months.

Comments: (GCD) 90% Distillation Point is severely high. (GCD) % < 335°C is marginally high.



Dec11/13

Base

Jan17/15

Jun 19/16




Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]

01/21/16

07/19/15

335°C is marginally high.



Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.

Please vent the low boiler vapors to atmosphere. The fluid is suitable for further use. Re-sample in 6 months. Indicate fluid service life at next sample. (GCD) % <

The fluid is in good condition and suitable for further use. Please re-sample in 6 months.