



HEAT TRANSFER

Customer: PTRHTF30101

Roseburg Pembroke MDF Inc. 777 Fibreboard Drive Pembroke, ON K8A 6W5 Canada

Attn: Jeff Kreiger Tel: (613)732-3939

E-Mail: vibration@pembrokemdf.com

System Information

System Volume: 100000 ltr

Bulk Operating Temp: 518F / 270C

Heating Source:

Blanket:

Fluid: PETRO CANADA PETRO-THERM

Make:

Sample Information


Lab No: 02179815 Analyst: Pierre Castagne Sample Date: 10/30/17 Received Date: 11/02/17 Completed: 11/23/17


To discuss this report contact Pierre

Castagne at 905-285-8278


Recommendation: Apart for high Iron, the sample looks good

Comments: PQ levels are abnormal. Iron ppm levels are abnormal. (GCD) 90% Distillation Point is marginally high.





10/30/17 05/12/17 05/11/17 Baseline Data Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments	
05/12/17	GCD @ 90% are very high, this impacts the viscosity and carbone deposit (GCD) 90% Distillation Point is severely high.
05/11/17	GCD @ 90% are very high, this impacts the viscosity and carbon deposits (GCD) 90% Distillation Point is severely high.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.