

KING PAVING HT SYST

Customer: PTRHTF30108

King Paving 1077 Howard Road

Burlington, ON L7R 3X5 Canada

Attn: Barry Messier Tel: (905)639-4401

E-Mail: bmessier@kpmindustries.com

System Information

System Volume: 2000 ltr

Bulk Operating Temp: Not Specified

Heating Source:

Blanket:

Fluid: PETRO CANADA PETRO-THERM

Make:

Sample Information


Lab No: 02185300 Analyst: Adam Koscielak Sample Date: 11/30/17 Received Date: 12/01/17 Completed: 12/07/17

To discuss this report contact Adam


Koscielak at 905-331-1323


Recommendation: High AN (Acid Number) indicates that oil is oxidized. Viscosity is lower than typical and indicates potential presence of lower boiling point material. GCD (Simulated Distillation) 90% result is higher than typical indicating fluid oxidation. High pentane insolubles indicates presence of solids in the fluid. Recommend flush and refill the system with new fluid.

Comments: Pentane Insolubles levels are abnormally high. Acid Number (AN) is severely high. (GCD) 90% Distillation Point is marginally high.









Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.