

WANSON 250LN

Customer: PTRHTF40022 MAYONNA BV NOORDGAT 1 FLEVOLAND

URK, FLE NETHERLANDS Attn: Maintenance Manager

Tel: E-Mail: System Information
System Volume: 0 gal

Bulk Operating Temp: Not Specified

Heating Source:

Blanket:

Fluid: PETRO CANADA PURITY FG HEAT TRANSFER FLUID

Make:

Sample Information

Lab No: 02185907 Analyst: Philip Riley Sample Date: 11/29/17 Received Date: 12/05/17 Completed: 12/11/17

To discuss this report contact Philip Riley

at (440)124-4378171


Recommendation: Flash Point off spec low, second year running. Viscosity also lower which confirms lighter molecules.

Recommended fluid change

Comments: COC Flash Point is severely low.











Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
11/29/17	12	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	16	0
05/24/16	28	0	0	0	1	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	31	1
01/22/15	22	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	1	0	0	42	0
Baseline Data			0	0						0			0	0	·				0	·			230	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]





	Historical Comments
05/24/16	Oil has a lower than expected Flash Point but GCD is fine. The oil is in good condition and fit for further service. Suggest sample at next scheduled maintenance interval. COC Flash Point is severely low.
01/22/15	Oil appears to be in good condition. Sample at next scheduled maintenance interval.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.