

## [CRESCENT POINT ENERGY / 9-16-1-14W2] FLAT LAKE HOT OIL SYSTEM

#### Customer: PTRHTF20180

CRESCENT POINT ENERGY 801 RAILWAY AVE W

CARLYLE, SK S0C 0R0 Canada

Attn: Jared Garnier

Tel: E-Mail:

jgarnier@crescentpointenergy.com

#### System Information

System Volume: 35000 ltr

Bulk Operating Temp: 347F / 175C

Heating Source:

Blanket:

Fluid: MONSANTO THERMINOL 55

Make: HEAT TECH

### Sample Information

Lab No: 02186971


Analyst: Kevin McDermott Sample Date: 12/01/17 Received Date: 12/08/17

Completed: 12/15/17

To discuss this report contact Kevin McDermott at (403)215-7052


Recommendation: Fluid remains in very good overall condition. No sign of free water that we saw in Jan 2017. Slight increase in GCD temps. Suggest annual sampling to be proactive.

Comments: (GCD) Distillation Points are increasing slightly, particularly the 90% value is in the 'abnormal' range.







Baseline Data



Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]





# **Historical Comments** Fluid is in very good condition. The only concern is the .2% free water. To be proactive, suggest submitting samples annually or sooner but only if the system conditions become severe. 01/24/17

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.