




WEST HOT OIL SYSTEM



Customer: PTRHTF10004	System Information	Sample Information
ADM VITAMIN E PLANT 3700 EAST DIVISION STREET DECATUR, IL 62526 USA Attn: Rick Cluck Tel: (217)451-7770 E-Mail: ricky.cluck@adm.com	System Volume: 2200 gal Bulk Operating Temp: 550F / 288C Heating Source: Blanket: Fluid: PETRO CANADA PURITY FG HEAT TRANSFER FLUID Make: AMERICAN	Lab No: 02190113 Analyst: Joe Goecke Sample Date: 12/18/17 Received Date: 12/27/17 Completed: 04/10/18 To discuss this report contact Joe Goecke at (859)543-0092

Recommendation: Sample remained very stable from last report. A slight drop in Flash point but a rise in viscosity indicates some stability. Low boilers had slight rise but less than 10. Continue to use and sample at next regular interval.

Comments: COC Flash Point is severely low. (GCD) 10% Distillation Point is abnormally low. (GCD) % < 335°C is marginally high.



Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
12/18/17	12/27/17	0y		271 / 133	9.1	25.2	0.03	0.040	644 / 340	798 / 425	907 / 486	8.86
11/21/17	11/22/17	2y		286 / 141	7.3	20.3	0.031	0.036	656 / 347	798 / 425	907 / 486	7.89
09/25/17	10/02/17	0y		275 / 135	4.1	25.1	0.33	0.036	635 / 335	800 / 427	917 / 491	9.48
08/14/17	08/22/17	0y	EAST PUMP WEST UNIT	349 / 176	21.2	25.3	0.02	0.045	632 / 334	796 / 425	907 / 486	9.71
07/05/17	07/11/17	0y	24B H.O. PUMP	342 / 172	19.3	21.1	0.089	0.033	627 / 331	798 / 426	910 / 488	10.04
05/22/17	05/26/17	0y	EAST PMP WEST UNIT	316 / 158	27.8	27.0	0.274	0.065	656 / 347	805 / 429	911 / 488	7.91
Baseline Data				459 / 237		37.12	0.90		721 / 383	807 / 431	892 / 478	1.5





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
12/18/17	3	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	16	0
11/21/17	1	0	0	0	0	0	1	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	28	0
09/25/17	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	7	0
08/14/17	7	0	0	0	0	0	1	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	7	17
07/05/17	2	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	7	0
05/22/17	4	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	9	19
Baseline Data			0	0						0			0	0					0				230	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments	
11/21/17	Drop in viscosity from last sample of 5 cSt, Flash point relatively the same slight decrease in low boilers indicate a fairly stable sample from last sample. Should consider a planned change out during next quarter due to the repeated low viscosity and high flash point. Resample in 45 days to confirm trend. COC Flash Point is severely low. Visc @ 40°C is abnormally low. (GCD) % < 335°C is marginally high. (GCD) 10% Distillation Point is marginally low.
09/25/17	Flash point has dropped by 40 degrees C and is extremely low. low boilers are steady from last sample and Viscosity remained unchanged. While the flash point is a concern I recommend resampling in 30 days with a possible plan to change in the next 60-90 days. COC Flash Point is severely low. (GCD) 10% Distillation Point is abnormally low. (GCD) % < 335°C is marginally high. (GCD) 90% Distillation Point is marginally high.
08/14/17	Sample looks very similar to last results. No action is required at this time. Although low boilers are approaching 10% they are slightly less than last month. Flash and viscosity slightly better than last month. Resample at planned interval, and I would still look at a change in the next 60-90 days. COC Flash Point is severely low. (GCD) 10% Distillation Point is abnormally low. (GCD) % < 335°C is marginally high.
07/05/17	Several Items need to be watched and system change out should be planned for the next quarter. Viscosity is low at 21 cSt, Low boilers have increased to 10% and Flash point although stable remains lower. To confirm trend resample in 30-45 days. (GCD) 10% Distillation Point is severely low. COC Flash Point is severely low. Visc @ 40°C is severely low. (GCD) % < 335°C is marginally high.
05/22/17	Low boilers continue to be on a slow rise, but viscosity and flash point have risen slightly since last sample possibly due to fresh oil top-up. Acid number has doubled since last sample. We suggest resampling at 3 months to watch for rapid rise in low boilers and decrease in flash point with a possible change in third or fourth quarter this year. COC Flash Point is severely low. (GCD) % < 335°C is marginally high. (GCD) 90% Distillation Point is marginally high. (GCD) 10% Distillation Point is marginally low.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.