

0793-06 PLASTICIZER HOT OIL UNIT

Customer: PTRHTF10191

Southwire Co. – SCBWP 3 Southwire Drive Carrollton, GA 30317 USA

Attn: Bill Rayfield Tel: (770)832-4741

E-Mail: bill.rayfield@southwire.com

System Information

System Volume: 165 gal Bulk Operating Temp: 240F / 116C

Heating Source:

Blanket:

Fluid: EASTMAN CHEMICAL THERMINOL 66

Make: ADVANTAGE


Sample Information

Lab No: 02193410 Analyst: Manny Garcia Sample Date: 01/09/18 Received Date: 01/18/18 Completed: 01/25/18

Recommendation: This system is a candidate for a complete fluid drain, flush and re-fill with Petro-Canada Calflo AF or Calflo LT. The system needs to be inspected to make sure there is no evidence of any carbon build-up on the tank walls/lines. We recommend a Cleaning if this material cannot be removed manually with Petro Canada Cleaning Fluid

Comments: The Acid Number correlates directly to the oil sample being oxidized at a 2.48 which is much higher then the limit of 1.0. Oxidation will increase the oils viscosity and make the fluid 'sludgy' as in the fact that the viscosity is higher by 32.4% which is unsatisfactory and was not flagged by the lab. Pentane insolubles are 'solids' found in this sample and the lab flagged this as unsatisfactory at 2.82. very Light debris found in the sample. Pentane Insolubles levels are severely high. Acid Number (AN) is severely high. (GCD) 90% Distillation Point is severely high. (GCD) % < 335°C is marginally high.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.