

## 0793-13 EXTRUDER HOT OIL

## Customer: PTRHTF10191

Southwire Co. – SCBWP 3 Southwire Drive Carrollton, GA 30317 USA

Attn: Bill Rayfield Tel: (770)832-4741

E-Mail: bill.rayfield@southwire.com

System Information
System Volume: 165 gal

Bulk Operating Temp: 350F / 177C

**Heating Source:** 

Blanket:

Fluid: EASTMAN CHEMICAL THERMINOL 66


Make:


Sample Information

Lab No: 02193412 Analyst: Manny Garcia Sample Date: 01/09/18 Received Date: 01/18/18 Completed: 01/25/18

Recommendation: This system should be drained, flushed and re-fill with Petro-Canada Calflo AF or Calflo LT. The system needs to be inspected to make sure there is no evidence of any carbon build-up on the tank walls/lines. We recommend a Cleaning if this material cannot be removed manually with Petro Canada Cleaning Fluid

Comments: The Acid Number is very close to the condemning limit of 1.0 at .875 and the oil proves to be oxidized. Oxidation will increase the oils viscosity and make the fluid `sludgy` as in the fact that the Pentane insolubles are unsatisfactory at 1.58 and flagged by the lab. These are 'solids` found in this sample. Zinc was found in the sample and that may be part of the plant's process or possibly a hydraulic oil that may have been topped off incorrectly. Pentane Insolubles levels are severely high. Acid Number (AN) is severely high. (GCD) 90% Distillation Point is severely high. Zinc ppm levels are severely high. (GCD) % < 335°C is abnormally high.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.