

## 0793-09 #2 BLENDER

## Customer: PTRHTF10191

Southwire Co. – SCBWP 3 Southwire Drive Carrollton, GA 30317 USA

Attn: Bill Rayfield Tel: (770)832-4741

E-Mail: bill.rayfield@southwire.com

## System Information

System Volume: 200 gal

Bulk Operating Temp: 240F / 116C

Heating Source:

Blanket:

Fluid: EASTMAN CHEMICAL THERMINOL 66


Make: ADVANTAGE


## Sample Information

Lab No: 02193413 Analyst: Manny Garcia Sample Date: 01/09/18 Received Date: 01/18/18 Completed: 01/25/18

Recommendation: This fluid should be considered for a drain, flush and re-fill with Calflo AF or Calflo LT.

Comments: This fluid has an increase in the viscosity of 19.9% and this is due to the oil oxidizing an becoming sludgy and less effective. The pentane insolubles are .1 which are solids that should not be in the system and are there due to oxidized fluids. Very light debris visible in fluid. (GCD) 90% Distillation Point is severely high. (GCD) 10% Distillation Point is abnormally high.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.