

[ATHABASCA OIL CORP / 05-27-078-10W4M] L3 (PAD C) LIESMER

Customer: PTRHTF20133

ATHABASCA OIL CORP.

LEISMER DEMONSTRATION PLANT

LSD2-79-10-W4M

NEAR CONKLIN, AB Canada

Attn: George Ball

Tel: x:

E-Mail: gball@atha.com

System Information

System Volume: 8000 ltr

Bulk Operating Temp: 212F / 100C

Heating Source:

Blanket:

Fluid: PETRO CANADA CALFLO LT

Make:

Sample Information


Lab No: 02199768 Analyst: Peter Harteveld Sample Date: 02/01/18 Received Date: 02/21/18 Completed: 02/27/18

To discuss this report contact Peter

Harteveld at (780)967-4234


Recommendation: The fluid is in good condition and suitable for further use. The low boiler vapor content in the fluid is slightly high (GCD% <335 = 41.92%). For the fresh fluid this is 35%. Please start venting low boiler vapor to atmosphere.Re-sample in 6 months.


Comments: (GCD) % < 335°C is marginally high.











Historical Comments	

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.