




## VAPOR POWER


Customer: PTRHTF30020	System Information	Sample Information
IKO INDUSTRIES HAWKESBURY 1451 SPENCE ROAD HI-PARTS-HAWK YARD HAWKESBURY, ON K6A 3T4 Canada Attn: FLORENTIN TOPA Tel: (613)632-8581 E-Mail: florentin.topa@iko.com	System Volume: 600 gal Bulk Operating Temp: 500F / 260C Heating Source: Blanket: Fluid: PETRO CANADA PETRO-THERM Make: VAPOR POWER	Lab No: 02199995 Analyst: Pierre Castagne Sample Date: 02/15/18 Received Date: 02/22/18 Completed: 03/08/18 To discuss this report contact Pierre Castagne at 450-981-0693

Recommendation: High boilers (GCD @ 90%) increase viscosity, as a result carbon deposit settle in low flow/disturbance areas and foul heat exchange surfaces. Looking at the curve, it appears that a low viscosity oil mixture has occurred.

Comments:



Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
02/15/18	02/22/18	243y		406 / 208	5.3	35.5	0.03	0.038	705 / 374	809 / 432	917 / 492	2.68
05/04/17	05/11/17	1y	HOT OIL BOILER	410 / 210	18.9	36.5	0.02	0.069	712 / 378	814 / 434	937 / 503	1.31
Baseline Data				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00





Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
02/15/18	6	0	0	0	1	0	0	6	0	0	0	0	0	0	0	0	0	0	0	0	6	0	0	0
05/04/17	11	0	0	1	1	0	0	18	0	0	1	0	0	0	0	0	0	0	0	0	18	0	0	0
<b>Baseline Data</b>			0	0						0			0	0					0				0	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments	
05/04/17	The sample has trace of Vanadium, the Low boilers GCD @10% are within specification (this could be the result of topping-up the oil) although the flash point is lower than the Petro-Therm oil specification (210°C versus 225°C specification), this suggests some oil craking is taking place. The High boilers GCD @ 90% are higher than the specification; this normally causes the viscosity of the oil to increase and carbon deposits. (GCD) 90% Distillation Point is severely high.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.