

## [NUVISTA CLAIRMONT / 08-10-68-08-W6] NUVISTA

## Customer: PTRHTF20175

QUADRA CHEMICALS 7802 98 STREET

CLAIRMONT, AB T0H 0W0 Canada

Attn: Daryl Key Tel: (780)296-0137

E-Mail: daryl key@quadra.ca

## System Information

System Volume: 2100 gal

Bulk Operating Temp: Not Specified

Heating Source:

Blanket:

Fluid: PETRO CANADA PETRO-THERM

Make:

## Sample Information


Lab No: 02200898 Analyst: Clinton Buhler Sample Date: 02/21/18 Received Date: 02/27/18 Completed: 03/01/18


To discuss this report contact Clinton

Buhler at 780-516-9920

Recommendation: Slightly reduced viscosity and flashpoint, along with reduced 90% distillation temperature can indicate thermal degradation (cracking) of the heat transfer fluid. Ensure that system is operating within design parameters and within the design limitations of the heat transfer fluid. Perform venting of the expansion tank to vent off the low boiling vapors. Resample fluid in 6-12 months

Comments: (GCD) 90% Distillation Point is marginally low.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.