

YONG SHUN PU U-9 U-10

Customer: PTRHTF60007

CANADIAN RESOURCES INC 2F 71 CHONG CHING NORTH ROAD S

C 3

TAIPEI, TAIWAN, PROVINC

Attn: HUGO CHENG Tel: (886)225-853509

E-Mail: roychen1018@hotmail.com

System Information

System Volume: 13120 ltr

Bulk Operating Temp: 419F / 215C

Heating Source:

Blanket:

Fluid: PETRO CANADA CALFLO HTF

Make:

Sample Information

Lab No: 02202462 Analyst: Yutong Gao Sample Date: 02/23/18 Received Date: 03/07/18 Completed: 03/10/18


To discuss this report contact Yutong


Nov29/16

Gao at (403)873-1876


Recommendation: The current fluid has normal viscosity, flash point. However, the TAN and solid content are higher than normal because of the minor oxidation. Please take one sample in 6 months to monitor the conditions. The fluid hours are not reported, which definitely limit our interpretation. Please inform Yutong Gao at Petro-Canada for the detailed fluid hours.

Comments: Acid Number (AN) is abnormally high. COC Flash Point is marginally low. (GCD) 90% Distillation Point is marginally low.













Sample Date	lron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
02/23/18	5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	60	0
11/29/16	3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	17	0
08/17/15	19	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	20	1
11/24/14	9	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	19	0
10/08/12	45	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	1	0	22	4
11/28/11	5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	0	0	0	9	0
Baseline Data			0	0						0			0	0					0				280	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]





Historical Comments							
11/29/16	The current fluid has adequate viscosity, flash point, acid number, distillation points, water and the solid content. The fluid is OK for continual run and please take a sample in 12 months to monitor the conditions.						
08/17/15	The current fluid has normal viscosity, GCD, TAN, solid and water. This fluid is suitable for further use. Please take one sample in one year to monitor the conditions. Please remember to provide the total fluid working hours when you send the future samples.						
11/24/14	The current fluid has normal viscosity, TAN, flash point and particle level. It is suitable for futher use. The lower 10% GCD is due to the mild thermal cracking. Please take one sample in 6 months to monitor the conditions. (GCD) 10% Distillation Point is marginally low.						
10/08/12	The oil appears to be in acceptable condition except the water content is excessively high at 0.37% (3700 ppm). We would like to see a confirmation sample to confirm the results. Please make sure to flush the sampling valve/piping with a few litres of oil before collecting the sample.						
11/28/11	The results look virtually identical to the last sample. Unless operational problems are experienced, we suggest to simply keep operating and re-sample in about 6 months to monitor the fluid condition.						

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.