





#2 FULTON FURNACE

Customer: PTRHTF10139

ARCHER DANIELS MIDLAND (ADM) 1251 BEAVER CHANNEL PKWY. CLINTON, IA 52732 USA

Attn: Tim Wiedner Tel: (563)244-6543

E-Mail: tim.wiedner.contractor@adm.com

System Information

System Volume: 750 gal

Bulk Operating Temp: 650F / 343C

Heating Source:

Blanket:

Fluid: HEAT TRANSFER FLUID ISO 46

Make:

Sample Information

Lab No: 02205581 Analyst: Neil Buchanan Sample Date: 01/23/18 Received Date: 03/22/18 Completed: 03/23/18

To discuss this report contact Neil Buchanan at 612-619-6571

Recommendation: Sample looks good and is suitable for further service. Resample next interval.


Comments: (GCD) 90% Distillation Point is marginally low.







Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments	
09/06/16	(GCD) 90% Distillation Point is elevated but fluid is fit for further service. Resample next interval.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.