



PILOT PLANT

Customer: PTRHTF30113

WOODLAND BIOFUELS 1086 MODELAND RD SARNIA, ON N7S 6L2 Canada

Attn: Jim Power Tel: (519)337-5398

E-Mail: jpower@woodlandbiofuels.com

System Information

System Volume: 100 ltr

Bulk Operating Temp: 392F / 200C

Heating Source:

Blanket:

Fluid: PETRO CANADA CALFLO LT

Make: CCI THERMAL TECH

Sample Information

Lab No: 02205770 Analyst: Lynn Billings Sample Date: 03/21/18 Received Date: 03/22/18 Completed: 03/26/18

To discuss this report contact Lynn

Billings at (289)523-0262

Recommendation: There appears to be a significant amount of water in your HTF system. (approximately 1102 ppm as well as some emulsified water - 0.2%) The GCD graph shows two peaks which indicates contamination of another product. This is why the 50% and 90% distillation values appear to be off.

Comments: Water contamination levels are severely high. (GCD) 90% Distillation Point is severely high. (GCD) 50% Distillation Point is marginally high.







Historical Comments	

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.