

## HMP2

Customer: PTRHTF30095

HP Pelzer 115 Industrial Way Athens, TN 37303 Canada

Attn: Conway Tabor Tel: (423)333-9402

E-Mail: ctabor@hppelzer.com

System Information

System Volume: 0 gal

Bulk Operating Temp: 425F / 218C

Heating Source:

Blanket:

Fluid: PETRO CANADA CALFLO AF

Make:

Sample Information


Lab No: 02207999 Analyst: Manny Garcia Sample Date: 03/22/18 Received Date: 04/03/18 Completed: 04/10/18


To discuss this report contact Manny

Garcia at 954-384-7259

Recommendation: 'Venting' the system may bring the 90% distillation point back down and increase the COC Flash point. If any maintenance is done on the system to mitigate these results, please re-submit samples. Please include the time on the unit and the time on the fluid on future sample labels and include the gallons in the reservoir.

Comments: (GCD) 90% Distillation Point is severely high. COC Flash Point is marginally low by 41oC.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.