

LWF #4

Customer: PTRHTF30095

HP Pelzer 115 Industrial Way Athens, TN 37303 USA Attn: Conway Tabor

Tel: (423)333-9402

E-Mail: ctabor@hppelzer.com

System Information

System Volume: 0 gal

Bulk Operating Temp: 425F / 218C

Heating Source:

Blanket:

Fluid: PETRO CANADA CALFLO AF

Make:

Sample Information


Lab No: 02211303 Analyst: Manny Garcia Sample Date: 04/12/18 Received Date: 04/20/18 Completed: 04/26/18

To discuss this report contact Manny


Garcia at 954-384-7259

Recommendation: This system may be a candidate for a system drain, flush and re-fill with new Petro-Canada Calflo AF heat transfer fluid for proper and safe operation of your unit. Please include the age of the fluid and the age of the unit on next year's used fluid sample. This allows for us to better interpret the results.

Comments: Iron ppm levels are abnormal. Pentane Insolubles levels are severely high. Visc @ 40°C is severely low 17.7 CsT @ 40°C. Acid Number (AN) is abnormally high (0.31). COC Flash Point is marginally low by 42°C.







Historical Comments	

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.