



KONUS #1, 2 & 3

Customer: PTRHTF20179

Canadian Forest Products 36654 Hart Highway General Delivery

Bear Lake, BC V0J 3G0 Canada

Attn: Robert J.C Bigham Tel: (778)349-3987

E-Mail: robert.bigham@canfor.com

System Information

System Volume: 120000 ltr

Bulk Operating Temp: 446F / 230C

Heating Source:

Blanket:

Fluid: PETRO CANADA PETRO-THERM

Make: KONUS

Sample Information

Lab No: 02213744 Analyst: Ray Rolston Sample Date: 04/25/18 Received Date: 05/02/18 Completed: 05/09/18

To discuss this report contact Ray

Rolston at (250)893-4496

Recommendation: Iron wear has remained at 57 ppm, while other wear metals are at low levels. The presence of additive metals sodium and calcium are unexpected, but their concentration has dropped since the last sample in October 2016. The oil's viscosity and Gas Chromatography Distillation (GCD) results have also improved since the last sample. The Total Acid Number (TAN) has increased to 0.66 mg KOH/g, above the condemning limit of 0.60, and Pentane Insolubles value of 4.88 (previously 5.99) suggests that the oil has oxidized and a significant volume of sediment is present. Petro-Canada Lubricants recommends that the Petro-Therm heat transfer fluid be drained, flushed and replaced as soon as practical.

Comments: Pentane Insolubles levels are severely high. Acid Number (AN) is severely high. Calcium ppm levels are severely high. Sodium ppm levels are abnormally high. Visc @ 40°C is abnormally high.







Baseline Data

10/24/16



Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]





Historical Comments

The sample shows a high level of acids through high Acid Number, a high amount of water as well as high concentrations of sodium and calcium. If this is truly a representative sample of what is flowing through this system this is extremely concerning. However, experience shows it might come from a sampling valve that was improperly flushed. Either way, we recommend to re-sample after making sure a good 4L (1 gal.) of oilis drained out before collecting the sample. Pentane Insolubles levels are severely high. ppm Water contamination levels are abnormally high. Water contamination levels are abnormally high. Sodium ppm levels are severely high. Calcium ppm levels are severely high. Visc @ 40°C is severely high. Acid Number (AN) is abnormally high. (GCD) 90% Distillation Point is abnormally high.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.