



WANSON BH/INC 1200

Customer: PTRHTF40127	System Information	Sample Information
Dalco Foods B.V Everdenberg 50 Oosterhout, 4902TT Netherlands Attn: Wilbert Snijers Tel: E-Mail: w.snijers@klt.nl	System Volume: 4200 gal Bulk Operating Temp: 518F / 270C Heating Source: Blanket: Fluid: PETRO CANADA PURITY FG HEAT TRANSFER FLUID Make: WANSON	Lab No: 02215802 Analyst: Philip Riley Sample Date: 05/08/18 Received Date: 05/11/18 Completed: 05/31/18 To discuss this report contact Philip Riley at (440)124-4378171

Recommendation: All parameters within expected and normal limits. Fluid fit for further use

Comments:

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
05/08/18	05/11/18	3d		432 / 222	36.1	34.2	0.44	0.053	688 / 364	793 / 423	907 / 486	4.98
Baseline Data				459 / 237		37.12	0.90		721 / 383	807 / 431	892 / 478	1.5



