




[Disto Oil Loop] SILANE 4.0 DISTILLATION COLUMN SAMPLE



| Customer: PTRHTF10093 | System Information | Sample Information |
|--|--|--|
| REC GROUP 3322 ROAD N N.E. MOSES LAKE, WA 98837 USA Attn: Sam Bright Tel: (509)766-8902 E-Mail: sam.bright@recsilicon.com | System Volume: 50000 gal Bulk Operating Temp: 420F / 216C Heating Source: Blanket: Fluid: PETRO CANADA CALFLO AF Make: COEN | Lab No: 02215919 Analyst: Ron LeBlanc Sample Date: 03/22/18 Received Date: 05/11/18 Completed: 05/22/18 To discuss this report contact Ron LeBlanc at (541)678-7044 |

Recommendation: Sample appears normal. (GCD) 90% Distillation Point is up marginally compared to last sample. PPM water has decreased from last sample. Both iron and pentane insoluble have dropped. Resample at normal interval.

Comments: (GCD) 90% Distillation Point is marginally high.



| Sample Date | Received Date | Fluid Age | Sample Location | Flash Point (COC) | Water (KF) | Viscosity (40°C) | Acid Number | Solids | GCD 10% | GCD 50% | GCD 90% | GCD % < 335°C |
|---------------|---------------|-----------|-----------------|-------------------|------------|------------------|-------------|--------|-----------|-----------|-----------|---------------|
| | mm/dd/yy | | | °F/°C | ppm | cSt | mg/KOH/g | %wt | °F/°C | °F/°C | °F/°C | % |
| 03/22/18 | 05/11/18 | 0m | | 403 / 206 | 17.3 | 30.8 | 0.045 | 0.072 | 654 / 346 | 778 / 415 | 910 / 488 | 6.99 |
| 09/23/16 | 09/26/16 | 2m | COLUMN | 424 / 218 | 19.0 | 30.5 | 0.087 | 0.183 | 695 / 369 | 796 / 424 | 889 / 476 | 1.29 |
| 07/07/16 | 07/12/16 | 49m | DISTO DCS | 129 / 54 | 0.00 | 15.9 | 0.06 | 0.085 | 560 / 294 | 784 / 418 | 909 / 487 | 13.16 |
| Baseline Data | | | | 435 / 224 | | 32.7 | 0.03 | | 693 / 367 | 790 / 421 | 887 / 475 | 2.5 |





| Sample Date | Iron | Chromium | Nickel | Aluminum | Copper | Lead | Tin | Cadmium | Silver | Vanadium | Silicon | Sodium | Potassium | Titanium | Molybdenum | Antimony | Manganese | Lithium | Boron | Magnesium | Calcium | Barium | Phosphorus | Zinc |
|----------------------|------|----------|--------|----------|--------|------|-----|---------|--------|----------|---------|--------|-----------|----------|------------|----------|-----------|---------|-------|-----------|---------|--------|------------|------|
| 03/22/18 | 54 | 0 | 0 | 0 | 0 | 1 | 0 | 0 | 0 | 0 | 5 | 0 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 195 | 0 |
| 09/23/16 | 116 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 14 | 1 | 0 | 0 | 0 | 0 | 1 | 0 | 0 | 0 | 0 | 0 | 288 | 1 |
| 07/07/16 | 20 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 15 | 0 |
| Baseline Data | | | 0 | 0 | | | | | | 0 | | | 0 | 0 | | | | | 0 | | | | 270 | |

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



Historical Comments

| | |
|----------|--|
| 09/23/16 | Iron elevated. Sample is normal otherwise. Iron ppm levels are noted. |
| 07/07/16 | The oil viscosity is about half of what it should be. The flash point of the oil is now extremely low. The oil contains a large amount of low boilers (13% by weight). Similar to the other 4.0 sample, if the entire charge of the system fluid looks like this sample it brings the difficult decision that the fluid should probably be replaced or do a significant sweetening to restore the flash point and other properties. (GCD) 10% Distillation Point is severely low. COC Flash Point is severely low. Visc @ 40°C is severely low. (GCD) % < 335°C is abnormally high. (GCD) 90% Distillation Point is marginally high. |
| | |
| | |

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.