

180511-4

Customer: PTRHTF30113

WOODLAND BIOFUELS 1086 MODELAND RD SARNIA, ON N7S 6L2 Canada

Attn: Jim Power Tel: (519)337-5398

E-Mail: jpower@woodlandbiofuels.com

System Information

System Volume: 10 ltr

Bulk Operating Temp: Not Specified

Heating Source:

Blanket:

Fluid: PENRECO DRAKEOL 10 Make: CCI THERMAL TECH

Sample Information


Lab No: 02216277 Analyst: Lynn Billings Sample Date: 05/11/18 Received Date: 05/15/18 Completed: 05/23/18

To discuss this report contact Lynn


Billings at (289)523-0262

Recommendation: Please confirm what the safe lower flash point operating level is for this fluid. You may want to vent the thermal fluid system to release any light ends in the fluid. Resample at the next service interval to monitor. This fluid is not Petro-Canada's and was run for contamination purposes with our fluid. Will need to do further comparison.

Comments: All component wear rates are normal. The water content is negligible. There is no indication of any contamination in the fluid. The AN level is acceptable for this fluid. The COC Flash Point is low for the Drakeol 10 product, but not for the Drakeol 10B. If you could confirm which product this is (there is no Drakeol LT 10 that we are aware of). There does appear to be some lower flash point products present in the fluid, and these do not look like degradation products, but more likely some type of foreign fluid.



Report ID: [02216277] (Generated: 05/23/2018 18:21:45) - Page 1 - Copyright 2018 Wearcheck Inc. All Rights Reserved.



WearCheck Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it.