

[PEYTO BRAZEAU PLANT / 100/6-12-44-13W5] H-1611 HEAT MEDIUM

Customer: PTRHTF20124

PEYTO EXPLORATION 11-17-55-21W5 BOX 7198

EDSON, AB T7E 1V4 Canada

Attn: Cory Pambrub Tel: (780)712-0217

E-Mail: cpambrun@peyto.com

System Information

System Volume: 0 ltr

Bulk Operating Temp: 383F / 195C

Heating Source:

Blanket:

Fluid: PETRO CANADA PETRO-THERM

Make: HEAT TECH

Sample Information


Lab No: 02216278 Analyst: Peter Harteveld Sample Date: 05/11/18 Received Date: 05/15/18 Completed: 05/17/18


To discuss this report contact Peter

Harteveld at (780)967-4234

Recommendation: The fluid is in good condition and suitable for further use. Viscosity and Flash Point are slightly low. % boil-off below 335C is slightly high. These parameters in combination with decreased 10%- and 50% GCD temperatures indicate thermal degradation of the fluid and/or ingress of blanket gas. At this moment it is not a problem but it is recommended to start venting-off low boiler vapors to atmosphere to bring the fluid back to a condition closer to the condition of fresh fluid. Venting should be part of regular maintenance. Please re-sample in 6 months.

Comments:





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.