


OLD SYSTEM


Customer: PTRHTF30115	System Information	Sample Information			
BI-AX INTERNATIONAL INC	System Volume: 400 ltr	Lab No: 02216882			
596 CEDAR ST	Bulk Operating Temp: Not Specified	Analyst: Lynn Billings			
WINGHAM, ON N0G 2W0 Canada	Heating Source:	Sample Date: 05/15/18			
Attn:	Blanket:	Received Date: 05/17/18			
Tel: (519)357-1818	Fluid: PETRO CANADA CALFLO AF	Completed: 05/25/18			
E-Mail:	Make:	To discuss this report contact Lynn			
		Billings at (289)523-0262			

Recommendation: GCD results are abnormal but this is also an ISO 22 grade of fluid. Petro-Canada does not carry an ISO 22. Fluid does show some iron at 52 ppm and a lot of sulfur at 318 ppm. Insufficient amount of fluid to run all tests.

Comments: Insufficient sample was received to conduct all the routine laboratory tests. (GCD) 90% Distillation Point is abnormally low. (GCD) % < 335°C is marginally high.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
05/15/18	05/17/18	0h			0.00	25.9	0.09		639 / 337	755 / 402	852 / 456	8.84
		Baseline	Data	435 / 224		32.7	0.03		693 / 367	790 / 421	887 / 475	2.5
Acid Number Visc			Viscosity	a 40°C	40°C Elach Doint (°C)							





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.

Report ID: [02216882] (Generated: 05/25/2018 17:48:11) - Page 2 - Copyright 2018 Wearcheck Inc. All Rights Reserved.