



H-920 STABILIZER 100/6-12-44-13W5

Customer: PTRHTF20124

PEYTO EXPLORATION 11-17-55-21W5 BOX 7198

EDSON, AB T7E 1V4 Canada

Attn: Brian Ford Tel: (780)712-2177 E-Mail: bford@peyto.com

System Information

System Volume: 500 ltr

Bulk Operating Temp: Not Specified

Heating Source:

Blanket:

Fluid: PETRO CANADA PETRO-THERM

Make: ALCO

Sample Information


Lab No: 02219733 Analyst: Peter Harteveld Sample Date: 05/29/18 Received Date: 05/31/18 Completed: 06/01/18

To discuss this report contact Peter

Harteveld at (780)967-4234

Recommendation: The fluid has a high water content. Percentage boil-off is elevated. AN is high for a fluid with only 2 service hours. The distillation curve is not representative for Petro-Therm. The 90% GCD temperature is low. All of these can be related to the high water content. Please boil-off the water and re-sample after doing this. When sending in the next sample please list the operating temperature of the fluid.

Comments: Water contamination levels are severely high. Water contamination levels are severely high. ppm Water contamination levels are severely high. (GCD) 90% Distillation Point is severely low. Acid Number (AN) is abnormally high.






150°C

100°C %0

%0





0.2

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.