



## [NEW - OFF TRUCK] ENERGY PLANT HOT OIL

Customer: PTRHTF20043	System Information	Sample Information
WEST FRASER LVI PO BOX 1737 ROCKY MT HOUSE, AB T4T 1B3 Canada Attn: Renny Ceccato Tel: E-Mail: renny.ceccato@westfraser.com	System Volume: 38000 ltr Bulk Operating Temp: 500F / 260C Heating Source: Blanket: Fluid: PETRO CANADA PETRO-THERM Make: WELLONS	Lab No: 02226006 Analyst: Gordon Susinski Sample Date: 06/08/18 Received Date: 07/04/18 Completed: 07/13/18 To discuss this report contact Gordon Susinski at (587)582-4118

Recommendation: Results are normal.

Comments:

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
06/08/18	07/04/18	0y		460 / 238	2.6	35.7	0.03	0.028	734 / 390	799 / 426	911 / 489	0.00
Baseline Data				433 / 223		34.2	0.03		720 / 382	817 / 436	900 / 482	1.00



