

LINE 2

Customer: PTRHTF40125

PKP - UKRAINE GAGRINA STR 39 RIVNE, 33003 Ukraine Attn: Sergey Protsyk

Tel:

E-Mail: eugenia@pkpua.com

System Information

System Volume: 17000 ltr Bulk Operating Temp: 527F / 275C

Heating Source:

Blanket:

Fluid: PETRO CANADA PETRO-THERM

Make: 1991 KONUS KESSEL

Sample Information

Lab No: 02230451 Analyst: Philip Riley Sample Date: 07/12/18 Received Date: 07/25/18 Completed: 08/08/18


To discuss this report contact Philip Riley

at (440)124-4378171

Recommendation: Flash Point by COC is low. There is significant presence of light end molecules as shown in GC, which will contribute to lower flash point. If can be done safely, consider venting and a partial oil change. If this cannot be done safely, should work towards an oil change

Comments: COC Flash Point is abnormally low.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.