



•	•	
Customer: PTRHTF20046	System Information	Sample Information
QUADRA CHEMICALS	System Volume: 50000 ltr	Lab No: 02231627
12925 146TH STREET	Bulk Operating Temp: 450F / 232C	Analyst: Clinton Buhler
EDMONTON, AB T5L 2H6 CANADA	Heating Source:	Sample Date: 07/09/18
Attn: Quadra Samples	Blanket:	Received Date: 08/01/18
Tel:	Fluid: PETRO CANADA CALFLO LT	Completed: 11/06/18
E-Mail: quadra_samples@quadra.ca	Make:	

Recommendation: This fill of Calflo LT is reported as having 21 days of service life. (new system/fill start-up ?) The watercontent is elevated. It is recommended to boil-off the water by venting to atmosphere. The low boiler vapor content (% <335C.) is high with 43%. (fresh = 35%) This can be influenced by the water content of the fluid.Please boil-off the water until thesteaming stops and re-sample after doing that.

Comments: Water contamination levels are marginally high. Water contamination levels are marginally high. ppm Water contamination levels are marginally high. (GCD) $\% < 335^{\circ}$ C is marginally high.







Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.

Report ID: [02231627] (Generated: 11/06/2018 11:04:22) - Page 2 - Copyright 2018 Wearcheck Inc. All Rights Reserved.