




[ATHABASCA OIL CORP / 05-27-078-10W4M] L3 (PAD C) LIESMER



| Customer: PTRHTF20133 | System Information | Sample Information |
|---|---|---|
| ATHABASCA OIL CORP. LEISMER DEMONSTRATION PLANT LSD2-79-10-W4M NEAR CONKLIN, AB Canada Attn: George Ball Tel: x: E-Mail: gball@atha.com | System Volume: 8000 ltr Bulk Operating Temp: 212F / 100C Heating Source: Blanket: Fluid: PETRO CANADA CALFLO LT Make: TORNADO TECHNOLOGIES | Lab No: 02233041 Analyst: Peter Harteveld Sample Date: 07/20/18 Received Date: 08/10/18 Completed: 08/16/18 |

Recommendation: The fluid is in good condition and suitable for further use. The low boiler vapor content is slightly high but has remained approximately the same as in the previous sample. Continuation of venting on a regular basis is recommended. Please re-sample in 6 months.

Comments: (GCD) % < 335°C is marginally high.



| Sample Date | Received Date | Fluid Age | Sample Location | Flash Point (COC) | Water (KF) | Viscosity (40°C) | Acid Number | Solids | GCD 10% | GCD 50% | GCD 90% | GCD % < 335°C |
|---------------|---------------|-----------|----------------------|-------------------|------------|------------------|-------------|--------|-----------|-----------|-----------|---------------|
| | mm/dd/yy | | | °F/°C | ppm | cSt | mg/KOH/g | %wt | °F/°C | °F/°C | °F/°C | % |
| 07/20/18 | 08/10/18 | 3y | +/- 100M FROM HEATER | 340 / 171 | 5.4 | 7.5 | 0.03 | 0.007 | 610 / 321 | 642 / 339 | 731 / 389 | 42.64 |
| 02/01/18 | 02/21/18 | 3y | | 338 / 170 | 1.9 | 7.4 | 0.01 | 0.008 | 609 / 321 | 642 / 339 | 732 / 389 | 41.92 |
| 07/22/17 | 08/08/17 | 0y | | 333 / 167 | 36.3 | 7.3 | 0.033 | 0.017 | 608 / 320 | 655 / 346 | 772 / 411 | 41.20 |
| 03/20/17 | 04/05/17 | 24y | | 322 / 161 | 8.5 | 7.4 | 0.02 | 0.033 | 611 / 322 | 645 / 341 | 735 / 390 | 36.95 |
| 06/19/16 | 07/05/16 | 18y | FLOW LINE | 329 / 165 | 6.7 | 7.5 | 0.09 | 0.013 | 611 / 322 | 647 / 342 | 742 / 394 | 36.53 |
| 01/21/16 | 02/11/16 | 0y | | 340 / 171 | 213.3 | 7.7 | 0.09 | 0.061 | 606 / 319 | 639 / 337 | 733 / 390 | 44.67 |
| Baseline Data | | | | 349 / 176 | | 7.52 | 0.1 | | 604 / 318 | 640 / 338 | 734 / 390 | 35.0 |





| Sample Date | Iron | Chromium | Nickel | Aluminum | Copper | Lead | Tin | Cadmium | Silver | Vanadium | Silicon | Sodium | Potassium | Titanium | Molybdenum | Antimony | Manganese | Lithium | Boron | Magnesium | Calcium | Barium | Phosphorus | Zinc |
|----------------------|------|----------|--------|----------|--------|------|-----|---------|--------|----------|---------|--------|-----------|----------|------------|----------|-----------|---------|-------|-----------|---------|--------|------------|------|
| 07/20/18 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 66 | 0 |
| 02/01/18 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 66 | 0 |
| 07/22/17 | 2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 37 | 0 |
| 03/20/17 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 38 | 0 |
| 06/19/16 | 5 | 0 | 0 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 45 | 0 |
| 01/21/16 | 19 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 87 | 0 |
| Baseline Data | | | 0 | 0 | | | | | | 0 | | | 0 | 0 | | | | | 0 | | | | 270 | |

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



| Historical Comments | |
|---------------------|--|
| 02/01/18 | The fluid is in good condition and suitable for further use. The low boiler vapor content in the fluid is slightly high (GCD% <335 = 41.92%). For the fresh fluid this is 35%. Please start venting low boiler vapor to atmosphere. Re-sample in 6 months. (GCD) % < 335°C is marginally high. |
| 07/22/17 | The fluid is in a good condition and suitable for further use. It does show some degradation indicated by a higher percentage of boil-off <335C and an elevated 90% GCD temperature. It is recommended to vent-off low boiler vapors to atmosphere at a regular interval. (suggestion is once a month) Please re-sample in 12 months. (GCD) 90% Distillation Point is severely high. (GCD) % < 335°C is marginally high. |
| 03/20/17 | The fluid is in good condition and suitable for further use. Please resample in 12 months. |
| 06/19/16 | The fluid is in good condition and suitable for further use. Please re-sample in 12 months. |
| 01/21/16 | Boil-off below 335 degrees C. has increased to 44.7%. This indicates an increased content of low boiler vapors as a result of thermal degradation of the fluid. Please vent the low boiler vapors to atmosphere. The fluid is suitable for further use. Re-sample in 6 months. Indicate fluid service life at next sample. (GCD) % < 335°C is marginally high. |

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.