

[PMI STATE HOT OIL SYS] 30073

Customer: PTRHTF30073

IRVING PAPER LTD 435 BAYSIDE DRIVE

SAINT JOHN, NB E2L 4K9 Canada

Attn: Terry Tomney Tel: (506)650-8435

E-Mail: tomney.terry@irvingpaper.com

System Information

System Volume: 3500 ltr

Bulk Operating Temp: 536F / 280C

Heating Source:

Blanket:

Fluid: PETRO CANADA PETRO-THERM

Make: METSO

Sample Information

Lab No: 02233913 Analyst: Claude Bureau Sample Date: 08/09/18 Received Date: 08/15/18 Completed: 08/22/18

To discuss this report contact Claude

Bureau at (438)863-7577

Recommendation: The (GCD) values are marginally to severely low levels. The flash point and viscosity are marginally low. These results are clearly a sign of a strong presence of a large quantity of light ends in the oil. The oil must be vented as soon as possible in order to remove these light ends. In order to follow the venting process please submit another sample after the venting cycle to re-evaluate the condition of the oil.

Comments: No wear metals detected. No contamination detected. (GCD) 50% Distillation Point is severely low. (GCD) 90% Distillation Point is severely low. (GCD) 10% Distillation Point is abnormally low. (GCD) % < 335°C is marginally high. COC Flash Point is marginally low (185°C). The viscosity is marginally low (26.3 cSt).






%0

%0

35% 40%

45% Percent Recovered





Aug9/18

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.

%09