

## **EAST SYSTEM**

## Customer: PTRHTF10182

American Cast Iron Pipe Co. 1501 31st Avenue North Birmingham, AL 35207 USA

Attn: Jeremy Mowry Tel: (205)325-7905

E-Mail: jmowry@american-usa.com

## System Information

System Volume: 5875 gal

Bulk Operating Temp: 540F / 282C

**Heating Source:** 

Blanket:

Fluid: PETRO CANADA PETRO-THERM

Make: WUERZ

## Sample Information

Lab No: 02234146 Analyst: Manny Garcia Sample Date: 07/23/18 Received Date: 08/16/18 Completed: 08/20/18


To discuss this report contact Manny


Garcia at 954-384-7259

Recommendation: Fluid is suitable for continued use.


Comments: (GCD) 90% Distillation Point is marginally low. 'Venting' the system could bring this value up to normal. Light debris noticed by the lab. Please change any system filters and/or filter the system fluid safely during any shutdowns with a portable kidney-loop filtration system.
















Sample Date	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
07/23/18	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	1
02/16/18	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	0	0	0	3
01/29/17	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	0	0	0	3
07/02/14	3	0	0	0	0	0	0	0	0	0	0	2	0	0	0	0	0	0	0	0	0	0	1	0
06/29/12	2	0	0	0	0	0	0	0	0	0	1	0	1	0	0	0	0	0	0	0	1	0	0	1
07/01/10	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Baseline Data			0	0						0			0	0					0				0	

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]





Historical Comments							
02/16/18	Fluid is suitable for continued use. Please re-submit annual sample of Petro-therm in May 2019. During a safe shutdown opportunity the fluid can be filtered with a kidney-loop filtration system to clean up any contamination. If system has any filters, please schedule them to be changed. Light Debris noticed in sample of fluid						
01/29/17	Fluid is suitable for continued use. 'Venting' the system may improve the 90% distillation point. Changing system filters or filtering fluid with a kidney loop system may reduce any 'debris' found in sample. Please include the age of the fluid and the age of the heat transfer system on next year's label. Re-submit fluid sample in May 2019Light debris seen in fluid sample. (GCD) 90% Distillation Point is abnormally low.						
07/02/14	The oil is still showing results that are normal and close to fresh oil. Contamination is minimal. Re-sample same time next year or before a maintenance shut down.						
06/29/12	The oil properties look very much like fresh oil. Keep up the good work. Try to sample every year if possible. We understand in this case it's like watching grass grow but trending data is key to an oil analysis program.						
07/01/10	The oil appears to be in acceptable condition for further service. We are noticing the oxidation level (Acid Number) is rising. Resample in 6-9 months to monitor the fluid condition.						

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.