



## HONG-TAI B2

Customer: PTRHTF60007	System Information	Sample Information
CANADIAN RESOURCES INC 2F 71 CHONG CHING NORTH ROAD S C 3 TAIPEI, TAIWAN, PROVINC Attn: HUGO CHENG Tel: (886)225-853509 E-Mail: roychen1018@hotmail.com	System Volume: 0 gal Bulk Operating Temp: Not Specified Heating Source: Blanket: Fluid: PETRO CANADA CALFLO AF Make:	Lab No: 02238024 Analyst: Yutong Gao Sample Date: 08/31/18 Received Date: 09/07/18 Completed: 09/14/18 To discuss this report contact Yutong Gao at (403)873-1876

Recommendation: The current fluid has adequate viscosity and flash point. However the acid number and solid contents are high due to the mild oxidation. Please continue to run this fluid and take one sample in 6 months to monitor the conditions.

Comments: Acid Number (AN) is abnormally high.

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/g	%wt	°F/°C	°F/°C	°F/°C	%
08/31/18	09/07/18	0h		410 / 210	36.8	38.5	0.45	1.59	693 / 367	792 / 422	893 / 478	1.16
Baseline Data				435 / 224		32.7	0.03		693 / 367	790 / 421	887 / 475	2.5



