

CROWLEY-SHEPPARD

Customer: PTRHTF10203

LEAHY-WOLF COMPANY 1724 W ARMITAGE COURT

SUITE A

ADDISON, IL 60101 USA

Attn: TERRY LONG

Tel:

E-Mail: terrylong@leahywolf.com

System Information

System Volume: 600 gal

Bulk Operating Temp: Not Specified

Heating Source:

Blanket:

Fluid: PETRO CANADA PETRO-THERM

Make:

Sample Information


Lab No: 02239069 Analyst: Yvette Trzcinski Sample Date: 08/30/18 Received Date: 09/13/18 Completed: 09/20/18


To discuss this report contact Yvette

Trzcinski at (262)933-0718

Recommendation: The fluid shows signs of oxidation and the potential to have heavy fouling sludge and corrosion in the system affecting the efficiency of the heat transfer system. The total acid number and the simulated distillation are all showing critically high levels at 90% and marginally high values at 50% and 10%

Comments: (GCD) 90% Distillation Point is severely high. Acid Number (AN) is abnormally high. (GCD) 10% Distillation Point is marginally high. (GCD) 50% Distillation Point is marginally high.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.