

[3-22-78-12W6] PH I/II Process heat medium

Customer: PTRHTF20203

BIRCHCLIFF ENERGY BOX 580, 5605 - 49TH

SPIRIT RIVER, AB T0H 3G0 Canada

Attn: Derek Michetti Tel: (250)719-8571

E-Mail: dmichetti@birchcliffenergy.com

System Information

System Volume: 19733 ltr

Bulk Operating Temp: 338F / 170C

Heating Source:

Blanket:

Fluid: PETRO CANADA PETRO-THERM

Make: Petro-Tech

Sample Information


Lab No: 02241817 Analyst: Clinton Buhler Sample Date: 09/19/18 Received Date: 09/27/18 Completed: 10/18/18


To discuss this report contact Clinton

Buhler at 780-516-9920

Recommendation: Sample results indicate that the fluid is suitable for continued service. % boil-off of 2.03% and slightly reduced flashpoint may be an indication of thermal degradation or possibly a mixture of fluids. As a good preventative maintenance practice, it is ideal to vent off any low boiling vapors from the system on a regular basis. Re-sample fluid in 6 months to establish a trend

Comments:





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.