




## HEAT TRANSFER



| Customer: PTRHTF10028  | System Information  | Sample Information   |
|--|---|--|
| PPG AEROSPACE<br>11601 UNITED ST<br>MOJAVE, CA 93501 USA<br>Attn: Phil Olson<br>Tel: (661)232-6814<br>E-Mail: phil.olson@ppg.com | System Volume: 0 gal<br>Bulk Operating Temp: 450F / 232C<br>Heating Source:<br>Blanket:<br>Fluid: PETRO CANADA CALFLO AF<br>Make: | Lab No: 02243238<br>Analyst: Steven Slanker<br>Sample Date: 09/24/18<br>Received Date: 10/04/18<br>Completed: 10/05/18<br>To discuss this report contact Steven Slanker at (951)225-2115 |

Recommendation: Iron has risen to 110 ppm and water to 331 ppm. Pentane insoluble are also high. If sample is representative of fluid in the system, check for pump wear and filter to remove wear metals, water, contaminants, and insoluble.

Comments: Iron ppm levels are marginal. Pentane Insolubles levels are abnormally high.



| Sample Date   | Received Date | Fluid Age | Sample Location      | Flash Point (COC) | Water (KF) | Viscosity (40°C) | Acid Number | Solids | GCD 10%   | GCD 50%   | GCD 90%   | GCD % < 335°C |
|---------------|---------------|-----------|----------------------|-------------------|------------|------------------|-------------|--------|-----------|-----------|-----------|---------------|
|               | mm/dd/yy      |           |                      | °F/°C             | ppm        | cSt              | mg/KOH/g    | %wt    | °F/°C     | °F/°C     | °F/°C     | %             |
| 09/24/18      | 10/04/18      | 0m        |                      | 392 / 200         | 331.4      | 29.2             | 0.18        | 0.396  | 689 / 365 | 786 / 419 | 883 / 473 | 1.98          |
| 05/02/16      | 05/13/16      | 18m       |                      | 349 / 176         | 9.1        | 29.5             | 0.17        | 0.111  | 680 / 360 | 798 / 425 | 897 / 480 | 4.46          |
| 07/10/15      | 07/21/15      | 7m        | DUPLEX FILTER EFFLNT | 370 / 188         | 9.3        | 28.0             | 0.139       | 0.050  | 675 / 357 | 797 / 425 | 902 / 483 | 4.95          |
| 01/05/15      | 01/21/15      | 64m       |                      | 406 / 208         | 8.5        | 28.6             | 0.149       | 0.040  | 680 / 360 | 800 / 427 | 903 / 484 | 4.29          |
| Baseline Data |               |           |                      | 435 / 224         |            | 32.7             | 0.03        |        | 693 / 367 | 790 / 421 | 887 / 475 | 2.5           |





| Sample Date          | Iron | Chromium | Nickel | Aluminum | Copper | Lead | Tin | Cadmium | Silver | Vanadium | Silicon | Sodium | Potassium | Titanium | Molybdenum | Antimony | Manganese | Lithium | Boron | Magnesium | Calcium | Barium | Phosphorus | Zinc |
|----------------------|------|----------|--------|----------|--------|------|-----|---------|--------|----------|---------|--------|-----------|----------|------------|----------|-----------|---------|-------|-----------|---------|--------|------------|------|
| 09/24/18             | 110  | 0        | 0      | 0        | 1      | 0    | 0   | 0       | 0      | 0        | 0       | 11     | 0         | 0        | 0          | 0        | 1         | 0       | 0     | 0         | 0       | 0      | 125        | 2    |
| 05/02/16             | 2    | 0        | 0      | 0        | 0      | 0    | 0   | 0       | 0      | 0        | 1       | 0      | 0         | 0        | 0          | 0        | 0         | 0       | 0     | 0         | 0       | 0      | 96         | 0    |
| 07/10/15             | 2    | 0        | 0      | 0        | 0      | 0    | 0   | 0       | 0      | 0        | 1       | 0      | 2         | 0        | 0          | 0        | 0         | 0       | 0     | 0         | 0       | 0      | 91         | 0    |
| 01/05/15             | 0    | 0        | 0      | 0        | 0      | 0    | 2   | 0       | 0      | 0        | 2       | 1      | 0         | 0        | 0          | 0        | 0         | 0       | 0     | 0         | 0       | 0      | 213        | 0    |
| <b>Baseline Data</b> |      |          | 0      | 0        |        |      |     |         |        | 0        |         |        | 0         | 0        |            |          |           |         | 0     |           |         |        | 270        |      |

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



| Historical Comments |   |
|---------------------|---|
| 05/02/16            | Purge low boilers from the system. Higher levels of sludge are observed on the filter paper. Continue monitoring filtration and change filters and needed. COC Flash Point is abnormally low. |
| 07/10/15            | The flash point is slightly below and GCD <335°C is slightly higher than normal. Recommend venting off low boilers to get flash point above 224°C. COC Flash Point is marginally low.         |
| 01/05/15            | Fluid suitable for continued use. Resample at normal interval.  |

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.