## [KEYERA PARTNERSHIP / 3-12-46-14W5M] TOTE B

## Customer: PTRHTF30084

Keyera Partnership Brazeau River Ga...

Box 7318

Drayton Valley, AB T7A 1S5 Canada

Attn: Don Renner Tel: (780)894-3601

E-Mail: don renner@keyera.com

## System Information

System Volume: 0 ltr

Bulk Operating Temp: Not Specified

Heating Source:

Blanket:

Fluid: PETRO CANADA PETRO-THERM

Make:

## Sample Information

Lab No: 02245901


Analyst: Kevin McDermott Sample Date: 10/11/18 Received Date: 10/18/18 Completed: 10/22/18


Kevin McDermott

kevin.mcdermott@hollyfrontier.com

Recommendation: Fluid is not suitable for use and should be disposed of - suspected contamination.

Comments: Water contamination levels are marginally high. (GCD) % < 335°C is severely high. (GCD) 90% Distillation Point is severely high. (GCD) 10% Distillation Point is severely low. COC Flash Point is severely low. Calcium ppm levels are severely high. Zinc and phosphorus and sulfur ppm levels are severely high. Acid Number (AN) is abnormally high. (GCD) 50% Distillation Point is abnormally high.





Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.