




SAINT-VITH PURATOS



| Customer: PTRHTF40077 | System Information | Sample Information |
|---|---|---|
| BRENNTAG NV NIJVERHFIDSLAAN 38 DEERLIJK, 8540 Belgium Attn: Bart Vandenberghe Tel: 3(247)586-5546 E-Mail: bart.vandenberghe@brenntag.be | System Volume: 15000 ltr Bulk Operating Temp: 565F / 296C Heating Source: Blanket: Fluid: PETRO CANADA PURITY FG HEAT TRANSFER FLUID Make: | Lab No: 02245907 Analyst: Philip Riley Sample Date: 09/10/18 Received Date: 10/18/18 Completed: 10/22/18 To discuss this report contact Philip Riley at (440)124-4378171 |

Recommendation: COC Marginally low and evidence of few lighter molecules to support this. Looks to be an oil change in the first place and there may be some slight carry over as part of this. All other fluid parameters hit normal limits. System is sampled 6 monthly so fluid fit for further use until next sample evaluation

Comments:



| Sample Date | Received Date | Fluid Age | Sample Location | Flash Point (COC) | Water (KF) | Viscosity (40°C) | Acid Number | Solids | GCD 10% | GCD 50% | GCD 90% | GCD % < 335°C |
|---------------|---------------|-----------|-----------------|-------------------|------------|------------------|-------------|--------|-----------|-----------|-----------|---------------|
| | mm/dd/yy | | | °F/°C | ppm | cSt | mg/KOH/g | %wt | °F/°C | °F/°C | °F/°C | % |
| 09/10/18 | 10/18/18 | 0m | | 381 / 194 | 13.8 | 30.8 | 0.54 | 0.026 | 719 / 382 | 798 / 425 | 890 / 477 | 0.00 |
| 04/17/18 | 05/01/18 | 16m | | 378 / 192 | 6.5 | 31.2 | 0.54 | 0.060 | 699 / 371 | 802 / 428 | 907 / 486 | 3.47 |
| 12/07/17 | 01/16/18 | 12m | | 367 / 186 | 11.6 | 31.9 | 0.702 | 0.037 | 710 / 377 | 802 / 428 | 899 / 481 | 2.22 |
| 09/04/17 | 09/12/17 | 9m | CHAUDIERE HAUT | 399 / 204 | 0.00 | 32.7 | 0.719 | 0.036 | 712 / 378 | 806 / 430 | 901 / 483 | 2.38 |
| 06/06/17 | 06/13/17 | 6m | CHAUDIERE HAUT | 392 / 200 | 6.8 | 32.8 | 0.51 | 0.032 | 717 / 380 | 812 / 433 | 906 / 486 | 1.96 |
| 01/27/17 | 02/07/17 | 2m | CHAUDIERE HAUT | 396 / 202 | 5.6 | 33.1 | 0.63 | 0.048 | 712 / 378 | 806 / 430 | 901 / 483 | 2.22 |
| Baseline Data | | | | 459 / 237 | | 37.12 | 0.90 | | 721 / 383 | 807 / 431 | 892 / 478 | 1.5 |





| Sample Date | Iron | Chromium | Nickel | Aluminum | Copper | Lead | Tin | Cadmium | Silver | Vanadium | Silicon | Sodium | Potassium | Titanium | Molybdenum | Antimony | Manganese | Lithium | Boron | Magnesium | Calcium | Barium | Phosphorus | Zinc |
|---------------|------|----------|--------|----------|--------|------|-----|---------|--------|----------|---------|--------|-----------|----------|------------|----------|-----------|---------|-------|-----------|---------|--------|------------|------|
| 09/10/18 | 4 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 7 | 0 |
| 04/17/18 | 8 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 8 | 0 |
| 12/07/17 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 4 | 0 |
| 09/04/17 | 10 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 11 | 0 |
| 06/06/17 | 8 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 10 | 0 |
| 01/27/17 | 6 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 12 | 0 |
| Baseline Data | | | 0 | 0 | | | | | | 0 | | | 0 | 0 | | | | | 0 | | | | 230 | |

Elemental analysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



| Historical Comments | |
|---------------------|--|
| 04/17/18 | All parameters within acceptable limits with exception of COC Flash point that is marginally low, however improved on previous sample. If possible and safe, please try to vent the system to reduce the light molecules and potentially elevate COC Flash Point. COC Flash Point is abnormally low. |
| 12/07/17 | marginally low on COC, but light ends look reduced from previous sample on GC trace. Looks to be sampled quarterly so fit for use until next quarter but must sample on time as flash poin has deteriorated in other samples in this system before change-out COC Flash Point is abnormally low. |
| 09/04/17 | Acid number creeping upwards from previous sample. Fluid darkened with use. IBP dropped, evidence of increased lighter molecules by GC, must monitor going forwards. Otherwise similar to last sample taken. COC Flash Point is marginally low. |
| 06/06/17 | Oil appears to be in good condition and fit for further service. Suggest sample at next scheduled maintenance interval. COC Flash Point is marginally low. |
| 01/27/17 | Oil appears to be in good condition and fit for further service. Suggest sample at next scheduled interval. COC Flash Point is marginally low. |

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.