


LINE 2 HOT OIL SYSTEM

Customer: PTRHTF10059	System Information	Sample Information
CERTAINTEED - SAINT GOBAIN	System Volume: 1265 gal	Lab No: 02247160
11519 US RT 250 N	Bulk Operating Temp: 480F / 249C	Analyst: Gaston Arseneault
MILAN, OH 44846 USA	Heating Source:	Sample Date: 10/11/18
Attn: DAVE BLAKELY	Blanket:	Received Date: 10/24/18
Tel: (419)541-0843	Fluid: PETRO CANADA CALFLO AF	Completed: 10/28/18
E-Mail: dave.l.blakely@saint-gobain.com	Make: FIRST THERMOL	To discuss this report contact Gaston
		Arseneault at 973-986-6503

Recommendation: The Acid Number test jumped to 0.2. While this is still a very low value and the test itself carries a certain uncertainty when measuring low values, the jump from 0.02 to 0.2 is noticeable in that perhaps oxidation has begun. We will monitor this property and if the trend of increasing Acid Number continues we will recommend to take action. Resample in 6 months.


Comments:

Sample Date	Received Date	Fluid Age	Sample Location	Flash Point (COC)	Water (KF)	Viscosity (40°C)	Acid Number	Solids	GCD 10%	GCD 50%	GCD 90%	GCD % < 335°C
	mm/dd/yy			°F/°C	ppm	cSt	mg/KOH/ g	%wt	°F/°C	°F/°C	°F/°C	%
10/11/18	10/24/18	Oy		417 / 214	14.3	36.0	0.195	0.207	694 / 368	786 / 419	880 / 471	0.00
04/19/18	04/27/18	0y	OFF OF HEADER	410 / 210	6.1	31.9	0.02	0.277	690 / 365	790 / 421	883 / 473	2.28
07/12/17	07/28/17	Оy		419 / 215	18.5	31.8	0.01	0.314	697 / 369	794 / 424	896 / 480	1.38
07/07/17	07/28/17	0y		406 / 208	15.1	32.0	0.01	0.289	696 / 369	794 / 423	895 / 479	1.43
02/07/17	02/15/17	Oy	SIDE STREAM FLTR PRT	410 / 210	8.7	32.2	0.05	0.145	696 / 369	793 / 423	900 / 482	1.18
05/29/16	06/07/16	Оy	SEALNAT USE TANK PMP	406 / 208	13.7	32.3	0.219	0.156	692 / 367	780 / 416	877 / 469	0.13
Baseline Data		435 / 224		32.7	0.03		693 / 367	790 / 421	887 / 475	2.5		






Elemental anaysis results (above) in parts per million (ppm). [10,000 ppm = 1.0%]



% Boiling < 335°C



Historical Comments

04/19/18	The condition of the oil looks very good. Please continue to sample at the same 8-9 months frequency.
07/12/17	Everything looks excellent, nothing is flagged. Pls resample at next scheduled interval.
07/07/17	Everything looks excellent, nothing is flagged. Pls resample at next scheduled interval.
02/07/17	The age of the fluid is unknown but it showed as 14 years old in 2014. The fluid looks very dark but its condition doesn't look that bad. We do not want to condemn 1200 gals of fluid based on looks only but if problems described last year with deposits in piping in low lying areas then a good system cleaning to restore its overall good condition should be considered.
05/29/16	The fluid looks very dark but its condition is not as bad as in 2014. Solids are not alarmingly high, oxidation is present but not at levels worth flagging or indicative of major problems. It came to our attention however that the system shows deposits in low lying piping and those signs should not be ignored. This oil analysis is just another tool in the toolbox but the challenge is to determine what the inside looks like based on a 1qt sample of hot oil.

Petro-Canada makes no representation or warranty of any kind, either express or implied, as to the accuracy or completeness of the analysis and assumes no responsibility and shall have no liability whatsoever with respect to such analysis, or a party's use of it. Petro-Canada is a division of HollyFrontier Corporation.